



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

11/3/2020

SUBJECT: SFD2008-0044
SINGLE FAMILY DWELLING

To: Triple A Homes

Here are the results of all Inspections located at **5036 CHRISTIAN LIGHT RD:**

Inspection Type: INSULATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: TAX INSPECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Tax Inspection
Result:
Remarks:
Notes:



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: WATER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time:
Completed Date/Time:
Inspector: EH Bucket
Result:
Remarks:
Notes:

Inspection Type: FINAL SFD CRAWL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks: not required
Notes:





Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Ray Holder
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 9/24/2020
Completed Date/Time: 9/24/2020
Inspector: Ray Holder
Result: APPROVED W/EXC
Remarks:
Notes: Need engineer letter stating footings are good.

Inspection Type: ADDRESS
Scheduled Date/Time: 9/24/2020
Completed Date/Time: 9/24/2020
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 5036 CHRISTIAN LIGHT RD FUQUAY VARINA 27526.





Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION
Scheduled Date/Time: 10/1/2020 Any
Completed Date/Time: 10/1/2020
Inspector: Ray Holder
Result: APPROVED
Remarks:
Notes: 9/29/2020 9:09 AM Triple A Homes, Inc.
Please call if any concerns. Logan - 984-225-0699
Contact Name: Triple A Homes, Inc.
Site Address: 5036 CHRISTIAN LIGHT RD
Phone: 9498120991
e-Mail: laura@tripleahomes.org

Inspection Type: T-POLE
Scheduled Date/Time: 10/1/2020 Any
Completed Date/Time: 10/1/2020
Inspector: Ray Holder
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/1/2020 7:15 AM Triple A Homes, Inc.

Contact Name: Triple A Homes, Inc.
Site Address: 5036 CHRISTIAN LIGHT RD
Phone: 9498120991
e-Mail: laura@tripleahomes.org

No premise number in file

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 10/5/2020 Any
Completed Date/Time: 10/5/2020
Inspector: Ray Holder
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/2/2020 12:06 PM Triple A Homes, Inc.

Contact Name: Triple A Homes, Inc.
Site Address: 5036 CHRISTIAN LIGHT RD
Phone: 9498120991
e-Mail: laura@tripleahomes.org

Missing I-joint blocking in 2 places, I circled on 1st floor layout.



Harnett County
108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 10/7/2020 Any
Completed Date/Time: 10/7/2020
Inspector: Ray Holder
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/6/2020 10:20 AM Triple A Homes, Inc.
Premise # 25901585
Contact Name: Triple A Homes, Inc.
Site Address: 5036 CHRISTIAN LIGHT RD
Phone: 9498120991
e-Mail: laura@tripleahomes.org

House in framing