



Living Room Door Header LP-LVL 2900Fb-2.0E 1.750" X 11.875" 2-Ply - PASSED Level: Level



**Member Information**

Type:	Girder
Plies:	2
Moisture Condition:	Dry
Deflection LL:	480
Deflection TL:	240
Importance:	Normal
Temperature:	Temp <= 100°F

Application:	Floor
Design Method:	ASD
Building Code:	IBC/IRC 2015
Load Sharing:	No
Deck:	Not Checked

**Reactions UNPATTERNED lb (Uplift)**

Brg	Live	Dead	Snow	Wind	Const
1	2015	2092	0	0	0
2	2015	2092	0	0	0

**Bearings**

Bearing	Length	Cap.	React D/L lb	Total	Ld. Case	Ld. Comb.
1 - SPF	3.500"	79%	2092 / 2015	4107	L	D+L
2 - SPF	3.500"	79%	2092 / 2015	4107	L	D+L

**Analysis Results**

Analysis	Actual	Location	Allowed	Capacity	Comb.	Case
Moment	12424 ft-lb	6'6"	19902 ft-lb	0.624 (62%)	D+L	L
Shear	3337 lb	1'2 5/8"	7897 lb	0.423 (42%)	D+L	L
LL Defl inch	0.194 (L/778)	6'6"	0.314 (L/480)	0.620 (62%)	L	L
TL Defl inch	0.395 (L/381)	6'6"	0.627 (L/240)	0.630 (63%)	D+L	L

**Design Notes**

- 1 Provide lateral support to prevent rotation at end bearings and at interior bearings when required by code for seismic design.
- 2 Dead Load Deflection: Instant = 0.201", Long Term = 0.301"
- 3 Girders are designed to be supported on the bottom edge only.
- 4 Multiple plies must be fastened together as per manufacturer's details.
- 5 Top loads must be supported equally by all plies.
- 6 Top must be continuously braced.
- 7 Bottom braced at bearings.

ID	Load Type	Location	Trib Width	Side	Dead 0.9	Live 1	Snow 1.15	Wind 1.6	Const. 1.25	Comments
1	Uniform			Top	310 PLF	310 PLF	0 PLF	0 PLF	0 PLF	Roof Truss Load
	Self Weight				12 PLF					

**Notes**

This component analysis is based on the loads, geometry and other conditions as entered by the user and listed in this report. The user is responsible to ensure the accuracy of the input and the applicability to the actual conditions of the structure for which this component is intended. This analysis is valid only for the product listed.  
Copyright 2019 All rights reserved by Louisiana Pacific Corp. 414 Union St Suite 2000, Nashville, TN 37219

**Manufacturer Info**

Louisiana-Pacific Corp  
414 Union Street, Suite 2000  
Nashville, TN 37219  
(888) 820-0325  
www.lpcorp.com  
APA: PR-L280, ICC-ES: ESR-2403,  
LADBS: RR-25783, Florida: FL15228

BMC/Locust Lumber Company  
312 E. Main Street, North Carolina  
28127  
704-888-4411



This design is valid until 10/31/2021