


**MBR Wdw Header LP-LVL 2900Fb-2.0E 1.750" X 9.250" 2-Ply - PASSED** Level: Level



**Member Information**

Type:	Girder	Application:	Floor
Plies:	2	Design Method:	ASD
Moisture Condition:	Dry	Building Code:	IBC/IRC 2015
Deflection LL:	480	Load Sharing:	No
Deflection TL:	240	Deck:	Not Checked
Importance:	Normal		
Temperature:	Temp <= 100°F		

**Reactions UNPATTERNED lb (Uplift)**

Brg	Live	Dead	Snow	Wind	Const
1	2050	2096	0	0	0
2	2050	2096	0	0	0

**Bearings**

Bearing	Length	Cap.	React D/L	Ib	Total	Ld. Case	Ld. Comb.
1 - SPF	3.500"	80%	2096 / 2050	4146	L	D+L	
2 - SPF	3.500"	80%	2096 / 2050	4146	L	D+L	

**Analysis Results**

Analysis	Actual	Location	Allowed	Capacity	Comb.	Case
Moment	9437 ft-lb	5'	12416 ft-lb	0.760 (76%)	D+L	L
Shear	3317 lb	9'	6151 lb	0.539 (54%)	D+L	L
LL Defl inch	0.182 (L/628)	5'	0.239 (L/480)	0.760 (76%)	L	L
TL Defl inch	0.369 (L/311)	5'	0.477 (L/240)	0.770 (77%)	D+L	L

**Design Notes**

- 1 Provide lateral support to prevent rotation at end bearings and at interior bearings when required by code for seismic design.
- 2 Dead Load Deflection: Instant = 0.186", Long Term = 0.280"
- 3 Girders are designed to be supported on the bottom edge only.
- 4 Multiple plies must be fastened together as per manufacturer's details.
- 5 Top loads must be supported equally by all plies.
- 6 Top must be continuously braced.
- 7 Bottom braced at bearings.

ID	Load Type	Location	Trib Width	Side	Dead 0.9	Live 1	Snow 1.15	Wind 1.6	Const. 1.25	Comments
1	Uniform			Top	410 PLF	410 PLF	0 PLF	0 PLF	0 PLF	Roof Truss Load
	Self Weight				9 PLF					

**Notes**

This component analysis is based on the loads, geometry and other conditions as entered by the user and listed in this report. The user is responsible to ensure the accuracy of the input and the applicability to the actual conditions of the structure for which this component is intended. This analysis is valid only for the product listed.  
Copyright 2019 All rights reserved by Louisiana Pacific Corp. 414 Union St Suite 2000, Nashville, TN 37219

**Manufacturer Info**

Louisiana-Pacific Corp  
414 Union Street, Suite 2000  
Nashville, TN 37219  
(888) 820-0325  
www.lpcorp.com  
APA: PR-L280, ICC-ES: ESR-2403,  
LADBS: RR-25783, Florida: FL15228

BMC/Locust Lumber Company  
312 E. Main Street, North Carolina  
28127  
704-888-4411



This design is valid until 10/31/2021