



**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

3/30/2021

**SUBJECT: SFD2008-0050**  
**SINGLE FAMILY DWELLING**

To: William Myers

Here are the results of all Inspections located at **1585 OAKRIDGE RIVER RD:**

Inspection Type: FOUNDATION SURVEY  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: CP Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: INSULATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Ray Holder  
Result:  
Remarks:  
Notes:

Inspection Type: OPEN FLOOR  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Ray Holder  
Result:  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Ray Holder  
Result:  
Remarks:  
Notes:



**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: TEMP POWER CERTIFICATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Ray Holder  
Result:  
Remarks:  
Notes:

Inspection Type: WATER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Ray Holder  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL SFD CRAWL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Ray Holder  
Result:  
Remarks:  
Notes:

Inspection Type: ENVIR OPERATIONS PERMIT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: EH Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: T-POLE  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Ray Holder  
Result:  
Remarks:  
Notes:



**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ROUGH IN  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Ray Holder  
Result:  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time: 10/20/2020  
Completed Date/Time: 10/20/2020  
Inspector: Ray Holder  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: T-POLE  
Scheduled Date/Time: 10/22/2020  
Completed Date/Time: 10/22/2020  
Inspector: Ray Holder  
Result: DISAPPROVED  
Remarks:  
Notes: Don't do stand alone T-pole inspection

Inspection Type: FOUNDATION  
Scheduled Date/Time: 11/10/2020  
Completed Date/Time: 11/10/2020  
Inspector: Ray Holder  
Result: APPROVED  
Remarks:  
Notes: Foundation and waterproofing

Inspection Type: ADDRESS  
Scheduled Date/Time: 11/23/2020  
Completed Date/Time: 11/25/2020  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks:  
Notes: 1585 OAKRIDGE RIVER RD FUQUAY VARINA 27526.



**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ROUGH IN

Scheduled Date/Time: 3/29/2021

Completed Date/Time: 3/29/2021

Inspector: Ray Holder

Result: DISAPPROVED

Remarks:

Notes:

1) fire caulk all penetrations 2) draft stop all draft blocking3) 2"square washers at garage wing walls 4) add kings to triple window in garage.