Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID: Lot #: File #:

Code:

51.0 2009 - OC

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Applicant: LCI HOMES Owner: Address: 217 Missike Sp. Date Evaluated: 64/16/2020 Design Flow (.1949): 360GPD Property Size: Proposed Facility: 3BL SFD Property Recorded: Location of Site: Public Individual Other Water Supply: ☐ Well ☐ Spring Evaluation Method: Auger Boring ☐ Pit ☐ Cut Type of Wastewater: Sewage ☐ Industrial Process ☐ Mixed

P R O F I L E	.1940 Landscape Position/ Slope %	Horizon Depth (ln.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1,2	L 3-4%	0-24	ca 45	F1 1558					P3
		24.48	OF SIL	EZ \$558		48			0.375
							1.0		
3	L 3-4%	, 0-18	61 45	UZ ~5~P					P5
		18.48	ge sic	TN 1558		46			0.375
							*		
	100 100								

Description	Initial	Repair System	Other Factors (.1946):
	System		Site Classification (.1948): PROUS INNACCT SUITABLE
Available Space (.1945)			Evaluated Rv:
System Type(s)	25% NED	25% NZD	Others Present:
Site LTAR	6.375	C-375	

COMMENTS: ____

LANDSCAPE POSITIONS	<u>GROUP</u>	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

SIC-SILTY CLAY 0.4 - 0.1 IV C-CLAY

SC-SANDY CLAY

STRUCTURE SG-SINGLE GRAIN M-MASSIVE CR-CRUMB GR-GRANULAR SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY PL-PLATY

MINERALOGY SLIGHTLY EXPANSIVE

EXPANSIVE

