



FIELD REPORT
FOUNDATION DEPARTMENT

PROJECT NAME: <u>Summit 2004</u>	PROJECT #: <u>2002 CD420</u>
PROJECT LOCATION: <u>SUNNYSIDE, NC</u>	SUMMIT REPRESENTATIVE: <u>[Signature]</u>
DATE: <u>12-22-2004</u>	PRESENT AT SITE:
CLIENT/CONTRACTOR: <u>[Signature]</u>	MILEAGE:
WORK PERFORMED: <u>1/2" SPT TESTING</u>	TOTAL TIME:

AS REQUESTED, SUMMIT REPRESENTATIVE REPORTED TO THE ABOVE REFERENCED SITE TO EVALUATE NEAR SURFACE FOUNDATION BEARING MATERIALS FOR THE PROPOSED:

LOT/BUILDING NUMBER: 275

ADDRESS: 170 S.W. 10th St.

PERMIT NUMBER: SFD 2003-0004

OUR TESTING AND OBSERVATIONS INDICATE THAT THE SOILS TESTED BY SUMMIT (ARE / ARE NOT) SUITABLE FOR THE:

MINIMUM ALLOWED BEARING CAPACITY OF 3000 PSF AT THIS TIME.

ACTION REQUIRED: Foundation needs cleaned out.

RETURN VISIT REQUIRED: YES/NO SIGNED (SUMMIT) [Signature]

SIGNED (CLIENT/CONTRACTOR IF REQUIRED): _____

ENGINEERING • LABORATORY • TESTING

3070 HARRING BUSINESS PLACE • SUITE 171 • RALEIGH, NC 27603 • (919) 380-9951 • (919) 380-9953 (FAX)

WWW.SUMMIT-COMPANIES.COM