



Hatch Legend	
Tray Ceiling	
Vaulted Ceiling	
Interior Bearing Walls	
Second Floor Walls	
Attic Room	

Products				
Net Qty	Plies	Product	Length	PlotID
2	2	1-3/4"x 11-7/8" LVL Kerto-S	10' 0"	BM1
2	2	1-3/4"x 23-7/8" LVL Kerto-S	22' 0"	GDH

Nail Information		Connector Information				
Truss	Header	Supported Member	Qty	Manuf	Product	Sym
16d/3-1/2"	16d/3-1/2"	Varies	5	USP	HUS26	

Dimension Notes	
1.	All exterior wall to wall dimensions are to face of sheathing unless noted otherwise
2.	All interior wall dimensions are to face of frame wall unless noted otherwise
3.	All exterior wall to truss dimensions are to face of frame wall unless noted otherwise

= Indicates Left End of Truss ▲  
(Reference Engineered Truss Drawing)  
Do Not Erect Trusses Backwards

Truss Placement Plan  
SCALE: NTS

LOAD CHART FOR JACK STUDS			
(BASED ON TABLES R502.5(1) & (2))			
NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADS/SPOUSE			
END REACTION (UP TO) 1700	END REACTION (UP TO) 2550	END REACTION (UP TO) 3400	END REACTION (UP TO) 4250
1	1	1	1
3400	5100	6800	8500
2	2	2	2
5100	7650	10200	12750
3	3	3	3
6800	10200	13600	17000
4	4	4	4
8500	12750	17000	
5	5	5	
10200	15300		
6			
11900			
7			
13600			
8			
15300			
9			

<b>BUILDER</b>	Signature Home Builders	<b>COUNTY</b>	Harnett
<b>JOB NAME</b>	Chis Foisy Residence	<b>ADDRESS</b>	Hobson Road, Dunn, NC
<b>PLAN</b>	Beaufort	<b>MODEL</b>	Roof
<b>SEAL DATE</b>	08/04/20	<b>DATE REV.</b>	09/21/20
<b>QUOTE #</b>	Quote #	<b>DRAWN BY</b>	Hampton Horrocks
<b>JOB #</b>	J0920-4348	<b>SALESMAN</b>	Anthony Williams

**THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.**  
These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature \_\_\_\_\_  
**Anthony Williams**

**ROOF & FLOOR TRUSSES & BEAMS**  
Reilly Road Industrial Park  
Fayetteville, N.C. 28309  
Phone: (910) 864-8787  
Fax: (910) 864-4444