

. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : ADAMS RESIDENCE 1-HEAD
Building : NEW RESIDENTIAL
Location : 219 HARVELL RD., COATS, NC
System : 1
Contract : 2020-XXX
Data File : 1ST FLR AREA 1 1-HEAD.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - ADAMS RESIDENCE Date - 12-09-20
 Location - 219 HARVELL RD., COATS, NC
 Building - NEW RESIDENTIAL System No. - 1
 Contractor - STE GENERAL CONTRACTOR, LLC Contract No. - 2020-XXX
 Calculated By - ROBERT LAWLEY Drawing No. - FP1
 Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
 OCCUPANCY - SINGLE FAMILY RESIDENCE NFPA 13D 2013

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
 Y Number of Sprinklers Flowing: (X)1 ()2 ()4 ()
 S ()Other
 T ()Specific Ruling Made by Date
 E
 M Listed Flow at Start Point - 20 Gpm System Type
 Listed Pres. at Start Point - 16.7 Psi (X) Wet () Dry
 D MAXIMUM LISTED SPACING 18 x 18 () Deluge () PreAction
 E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
 S Additional Flow Added - 0 Gpm Make TYCO Model LFII
 I Elevation at Highest Outlet - 9 Feet Size 1/2 K-Factor 4.9
 G Note:SAFETY MARGIN: 33 PSI Temperature Rating 155*
 N 6 PSI ADDED FOR WATER METER LOSS

Calculation	Gpm Required 21	Psi Required 52	At Test
Summary	C-Factor Used:	Overhead 150	Underground 150

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 12-09-20	Rated Cap.	Cap.
T	Time of Test - 10:10 AM	@ Psi	Elev.
E	Static (Psi) - 85	Elev.	
R	Residual (Psi) - 20	Other	Well
	Flow (Gpm) - 530		Proof Flow Gpm
S	Elevation - 0		

P Location: 6" MAIN ON BRICK MILL RD.
 P
 L Source of Information: TESTED BY RELIABLE FIRE PROTECTION
 Y


Water Supply Curve C

Reliable Fire Protection LLC
ADAMS RESIDENCE 1-HEAD

Page 2
Date 11-24-20

City Water Supply:
C1 - Static Pressure : 85
C2 - Residual Pressure: 20
C2 - Residual Flow : 530


Demand:
D1 - Elevation : 3.898
D2 - System Flow : 20.024
D2 - System Pressure : 51.009
Hose (Demand) : _____
D3 - System Demand : 20.024
Safety Margin : 33.839



Flow Diagram

Reliable Fire Protection LLC
ADAMS RESIDENCE 1-HEAD

Page 3
Date 11-24-20



Fittings Used Summary

Reliable Fire Protection LLC
ADAMS RESIDENCE 1-HEAD

Page 4
Date 11-24-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
N*	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O*	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zwa	Watts 007	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
ADAMS RESIDENCE 1-HEAD

Page 5
Date 11-24-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
H1	9.0	4.9	16.7	na	20.02	0.05	400	16.7
1	9.0		17.21	na				
4	9.0		19.67	na				
5	9.0		19.72	na				
TOR	9.0		23.06	na				
BOR	1.0		32.86	na				
TAP	0.0		50.85	na				
UG1	0.0		51.01	na				
TEST	0.0		51.01	na				


The maximum velocity is 6.75 and it occurs in the pipe between nodes H1 and 1

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
ADAMS RESIDENCE 1-HEAD

Page 6
Date 11-24-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H1 to 1	9 9	4.90	20.02 20.02	1 1.101	1N 0.0 0.0	7.0 0.0 7.500	150 0.0681	16.700 0.0 0.511		Vel = 6.75	
1			0.0 20.02					17.211		K Factor = 4.83	
* 1 to 4	9 9		20.02 20.02	1 1.101	1O 0.0 0.0	5.0 5.000 36.000	150 0.0682	17.211 0.0 2.455		Vel = 6.75	
4 to 5	9 9		0.0 20.02	1 1.101	0.0 0.0 0.0	0.833 0.0 0.833	150 0.0684	19.666 0.0 0.057		Vel = 6.75	
5 to TOR	9 9		0.0 20.02	1 1.101	2N 0.0 0.0	14.0 14.000 49.000	150 0.0682	19.723 0.0 3.342		Vel = 6.75	
TOR			0.0 20.02					23.065		K Factor = 4.17	
* TOR to BOR	9 1		20.02 20.02	1 1.101	1Zwa 0.0 0.0	8.000 0.0 8.000	150 0.0681	23.065 9.248 0.545		** Fixed Loss = 5.783 Vel = 6.75	
BOR to TAP	1 0		0.0 20.02	1 1.101	1O 1T 0.0	5.0 9.563 169.562	150 0.0682	32.858 6.433 11.563		** Fixed Loss = 6 Vel = 6.75	
TAP to UG1	0 0		0.0 20.02	4 4.1	1F 1T 0.0	5.813 29.067 1201.880	1167.000 34.880 0.0001	140 0.0 0.155		Vel = 0.49	
UG1 to TEST	0 0		0.0 20.02	6 6.16	0.0 0.0 0.0	36.000 0.0 36.000	140 0	51.009 0.0 0.0		Vel = 0.22	
TEST			0.0 20.02					51.009		K Factor = 2.80	



. . . Fire Protection by Computer Design

Reliable Fire Protection LLC
32 Partin Rd.
Dunn, NC 28334
Robert Lawley
NICET Level III #103122

Job Name : ADAMS RESIDENCE 2-HEAD
Building : NEW RESIDENTIAL
Location : 219 HARVELL RD., COATS, NC
System : 1
Contract : 2020-XXX
Data File : 1ST FLR AREA 1 2-HEAD.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - ADAMS RESIDENCE Date - 12-09-20
Location - 219 HARVELL RD., COATS, NC
Building - NEW RESIDENTIAL System No. - 1
Contractor - STE GENERAL CONTRACTOR, LLC Contract No. - 2020-XXX
Calculated By - ROBERT LAWLEY Drawing No. - FP1
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - SINGLE FAMILY RESIDENCE NFPA 13D 2013

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 12 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 12 x 12 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO Model LFII
I Elevation at Highest Outlet - 10 Feet Size 1/2 K-Factor 4.9
G Note:SAFETY MARGIN: 31 PSI Temperature Rating 155*
N 6 PSI ADDED FOR WATER METER LOSS

Calculation Gpm Required 27 Psi Required 54 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 12-09-20 Rated Cap. Cap.
T Time of Test - 10:10 AM @ Psi Elev.
E Static (Psi) - 85 Elev.
R Residual (Psi) - 20 Other Well
Flow (Gpm) - 530 Proof Flow Gpm
S Elevation - 0

P Location: 6" MAIN ON BRICK MILL RD.

P
L Source of Information: TESTED BY RELIABLE FIRE PROTECTION
Y

Water Supply Curve C

Reliable Fire Protection LLC
ADAMS RESIDENCE 2-HEAD


Page 2
Date 11-24-20

City Water Supply:

C1 - Static Pressure : 85
C2 - Residual Pressure: 20
C2 - Residual Flow : 530

Demand:



D1 - Elevation : 4.331
D2 - System Flow : 26.459
D2 - System Pressure : 53.400
Hose (Demand) : _____
D3 - System Demand : 26.459
Safety Margin : 31.346



Flow Diagram

Reliable Fire Protection LLC
ADAMS RESIDENCE 2-HEAD

Page 3
Date 11-24-20



Fittings Used Summary

Reliable Fire Protection LLC
ADAMS RESIDENCE 2-HEAD

Page 4
Date 11-24-20

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zwa	Watts 007	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC
ADAMS RESIDENCE 2-HEAD

Page 5
Date 11-24-20

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
H2	10.0	4.9	7.0	na	12.96	0.05	144	7.0
H3	10.0	4.9	7.59	na	13.5	0.05	144	7.0
2	10.5		7.01	na				
3	10.5		7.79	na				
5	9.0		11.37	na				
TOR	9.0		16.97	na				
BOR	1.0		27.34	na				
TAP	0.0		53.14	na				
UG1	0.0		53.4	na				
TEST	0.0		53.4	na				

The maximum velocity is 8.92 and it occurs in the pipe between nodes 3 and 5

Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC
ADAMS RESIDENCE 2-HEAD

Page 6
Date 11-24-20

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H2 to 2	10 10.500	4.90	12.96 12.96	1 1.101	1N 7.0 0.0 0.0	0.500 7.000 7.500	150	7.000 -0.217 0.229		Vel = 4.37	
2			0.0 12.96					7.012		K Factor = 4.89	
H3 to 3	10 10.500	4.90	13.50 13.5	1 1.101	1N 7.0 1O 5.0 0.0	0.833 12.000 12.833	150	7.585 -0.217 0.422		Vel = 4.55	
3			0.0 13.50					7.790		K Factor = 4.84	
*											
2 to 3	10.500 10.500		12.96 12.96	1 1.101	2N 14.0 0.0 0.0	11.500 14.000 25.500	150	7.012 0.0 0.778		Vel = 4.37	
3 to 5	10.500 9		13.50 26.46	1 1.101	2N 14.0 1O 5.0 0.0	6.667 19.000 25.667	150	7.790 0.650 2.931		Vel = 8.92	
5 to TOR	9 9		0.0 26.46	1 1.101	2N 14.0 0.0 0.0	35.000 14.000 49.000	150	11.371 0.0 5.595		Vel = 8.92	
TOR			0.0 26.46					16.966		K Factor = 6.42	
*											
TOR to BOR	9 1		26.46 26.46	1 1.101	1Zwa 0.0 0.0 0.0	8.000 0.0 8.000	150	16.966 9.465 0.914		** Fixed Loss = 6 Vel = 8.92	
BOR to TAP	1 0		0.0 26.46	1 1.101	1O 5.0 1T 9.563 0.0	155.000 14.562 169.562	150	27.345 6.433 19.362		** Fixed Loss = 6 Vel = 8.92	
TAP to UG1	0 0		0.0 26.46	4 4.1	1F 5.813 1T 29.067 0.0	1167.000 34.880 1201.880	140	53.140 0.0 0.259		Vel = 0.64	
UG1 to TEST	0 0		0.0 26.46	6 6.16	0.0 0.0 0.0	36.000 0.0 36.000	140	53.399 0.0 0.001		Vel = 0.28	
TEST			0.0 26.46					53.400		K Factor = 3.62	