

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460

April 7, 2021

Subject: Connelly Residence
Scott Plan Review Letter
Harnett County Permit #: SFD 2009-0053

Based on the request of the County Inspector, I reviewed the header sizes for the Garage Door openings. My recommendations are as follows:

- The proposed double 2x12 header, with 2 jack studs under each end, for the Garage Door openings (9') is acceptable.

The double 2x12 header meets all the requirements of the 2018 North Carolina Building Code for Residences.



04 07 2021

Signature Certificate

Folder Ref: 600e9385cb269b184883b8ccb1694d1f2b03440f



Author: Joel S. Howerton

Creation Date: 07 Apr 2021, 11:59:53, EDT

Completion Date: 07 Apr 2021, 12:01:51, EDT

Document Details:



Name: Connelly Residence Plan Review Letter

Type:

Document Ref: 99cad9e91234dbbad4f5f8e542ffdeca085699a735498ddf08e817acdae7b660

Document Total 1
Pages:

Document Signed By:

Name: Joel S. Howerton
Email: joeltarheel66@yahoo.com
IP: 2600:1700:ba3:4100:5845:f454:6be7:1c12
Location: RALEIGH, NC (US)
Date: 07 Apr 2021, 12:01:51, EDT
Consent: eSignature Consent Accepted
Security Level: Email

Document History:

Folder Created Joel S. Howerton created this folder on 07 Apr 2021, 11:59:53, EDT
Invitation Sent Invitation sent to Joel S. Howerton on 07 Apr 2021, 12:01:45, EDT
Invitation Accepted Invitation accepted by Joel S. Howerton on 07 Apr 2021, 12:01:45, EDT
Signed By Joel S. Howerton Joel S. Howerton signed this folder on 07 Apr 2021, 12:01:51, EDT
Executed Document(s) successfully executed on 07 Apr 2021, 12:01:51, EDT
Signed Document(s) Emailed to joeltarheel66@yahoo.com

