

October 16, 2020

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

Mario Nava Miranda
110 Old Mail Lane
Coats, NC 27521

RE: Existing Tank Application # SFD2009-0056

Mr. Miranda:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other –Unable to approve. Tank lid appears to be open but full to surface of ground water on multiple visits. Integrity of tank unknown. Entire tank top shall be uncovered and pumped to examine if tank meets current septic system standards. Advised to provide private septic inspection prior to proceeding. Health Department cannot guarantee function of septic system.

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting