

October 27, 2020

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Weaver Homes Inc  
350 Wagoner Drive  
Fayetteville, NC 28303

ph: 910-893-7547  
fax: 910-893-9371

**Re: Status of Improvement Permit Application: SFD2010-0013**

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- **Previous home was located in approximate footprint of new home. Applicant applied that no existing septic, wells, electrical located on lot. Existing septic system shall be located or documented location of previous abandonment. Reconfirm/revise when ready. Call with any questions, comments, or concerns.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy: Central Permitting