

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: **3 BDRM** Design Flow (.1949): **360 gpd** Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-46"	GS						5.8
2		0-18"	GS						
		14"	MC						U5
3		0-20"	GS	VFR NSHP					PS .24
		20-36"	SBX GCL	FR SS/SP					
4		0-12"	GS	VFR NSHP					
		12-40"	SBX SCU	FR SS/SP					PS .24
5		0-18"	GS	VFR NSHP					
		18-40"	SBX SCU	FR SS/SP					PS .24

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OS Others Present:
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	25" x 10" R60		
Site LTAR	.24	.24	

1st 25" x 10" DRAIN REQUIRED