
## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 48 Cedarview Ct SUBDIVISION Carolina Seasons ISSUED TO: MRH Land Holding NEW 🔀 EXPANSION Site Improvements required prior to Construction Authorization Issuance: REPAIR 🗍 Type of Structure: SFR Proposed Wastewater System Type: Pump to 25% reduction Projected Daily Flow: 360 \_\_ GPD Number of Occupants: 6 \_\_\_\_\_max Number of bedrooms: 3\_ Basement Yes ⊠ No ☐ No May be required based on final location and elevations of facilities Pump Required: XYes ▼ Five years Type of Water Supply: Community Dublic Well Distance from well feet Permit valid for: No expiration \_\_\_\_ Date: 11-20-2020 SEE ATTACHED SITE SKETCH Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules . 1950, . 1952, . 1954, . 1955, . 1956, . 1957, . 1958, and . 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 48 Cedarview Ct ISSUED TO: MRH Land Holding LOT # 6 SUBDIVISION carolina Seasons Expansion Facility Type: SFR ✓ New Basement Fixtures? Tyes ⊠ No Basement? Yes Pump to 25% reduction (Initial) Wastewater Flow: 360 GPD Type of Wastewater System\*\* (See note below, if applicable ) Pump to 25% or 50% reduction (Repair) Number of trenches 1 Installation Requirements/Conditions Exact length of each trench 225 Trench Spacing: 9 Feet on Center Septic Tank Size 1000 gallons Soil Cover: 6 inches Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18-28 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) \_\_ inches below pipe Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_\_\_ \_\_\_\_\_inches above pipe 12 inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO LITILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 11-20-2020 Authorized State Agent: Construction Authorization Expiration Date: 11-20-25

## Harnett County Department of Public Health Site Sketch

Property Location: 48 Cedarview Ct.		
Issued To: MRH Land Holding	Subdivision Carolina Seasons	Lot # 6
Authorized State Agent: Mal M	- REHI	Date: <u>11-20-2020</u>



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.