Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID: Lot #: File #:

Code:

SFD2010-0058

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

SCUTH CREAM Applicant: SIGNATURE HOME BLOS Owner: Address: 125 25160 57 Date Evaluated: 11/10/2020 Design Flow (.1949): 4800FD LOT 58 Proposed Facility: Property Recorded: Property Size: Location of Site: Water Supply: Public Individual ☐ Spring Other ☐ Pit Evaluation Method: Auger Boring > Sewage ☐ Industrial Process Type of Wastewater: Mixed

P R O F I L E	.1940 Landscape Position/ Slope %	Horizon Depth (ln.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
2,3	L3-5%	6-12	en es	un soul					62
11		12-48	BU SLL	47 200P FN 5P		48			0.35
-									
					==				
3									

Description	Initial	Repair System	Other Factors (.1946):	
	System		Site Classification (.1948):	PRONTINALLY SUITABLE
Available Space (.1945)	1		Evaluated By:	
System Type(s)	2570 185	25% NES	Others Present:	ANDREW CUMIN, NEHS
Site LTAR	0.35	0.35		

COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	<u>TEXTURES</u>	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	1	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		

STRUCTURE
SG-SINGLE GRAIN
M- MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY
PR-PRISMATIC

MINERALOGY SLIGHTLY EXPANSIVE

EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North) 5=5 ENDIGO STREET