

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: *MRH Land Holding* Applicant:
 Address: *186 Wildwood Way*
 Proposed Facility: *SFR*
 Location of Site: *same*

Date Evaluated: *11-4-2020*
 Design Flow (.1949): *360 GPD*
 Property Recorded:

Property Size:

** recommend moving house
 back by 40' to gain
 access to suitable soils
 for Drain Field + R.A.*

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS					Profile Class & LTAR
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz		
			.1941 Structure/ Texture	.1941 Consistence Mineralogy						
1	<i>L 2-5%</i>	<i>0-10</i>	<i>LS Gr</i>	<i>Fr/ns/NP/NXP</i>	<i>7.5YR 7/2</i>	<i>>48"</i>	<i>-</i>	<i>-</i>	<i>PS .4 Group III</i>	
		<i>10-48</i>	<i>SC SBk</i>	<i>Fi/ss/SP/SP</i>	<i>@ 22"</i>					
2	<i>L 2-5%</i>	<i>0-4</i>	<i>LS Gr</i>	<i>Fr/ns/NP/NXP</i>	<i>7.5YR 7/2 @</i>	<i>>48"</i>	<i>-</i>	<i>-</i>	<i>U</i>	
		<i>4-48</i>	<i>SC SBk</i>	<i>Fi/ss/SP/SP</i>	<i><12"</i>					
3-5	<i>L 2-5%</i>	<i>0-16</i>	<i>LS Gr</i>	<i>Fr/ns/NP/NXP</i>	<i>>48"</i>	<i>>48"</i>	<i>-</i>	<i>-</i>	<i>S .6 Group II</i>	
		<i>16-48</i>	<i>SL Gr</i>	<i>Fr/ns/NP/NXP</i>						

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): <i>Melburn REHS</i>
System Type(s)	<i>25% ind</i>	<i>25% red</i>	Evaluated By: <i>J.M.</i>
Site LTAR	<i>.6</i>	<i>.6</i>	Others Present:

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM		SP-SLIGHTLY STICKY	
CC-CONCLAVE SLOPE		CL-CLAY LOAM		P-PLASTIC	
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM		VP-VERY PLASTIC	
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

EP+CA

Show profile locations and other site features (dimensions, references or benchmark, and North)

