




1731 Round Rock Drive, Raleigh, NC 27615 • (919) 872-3250 • fax (919) 877-5775 • www.flsamerica.com

OAKHAVEN LOT 01

HYDRAULIC CALCULATIONS

4/22/2021



Hydraulic calculations using HydraCALC

Fire & Life Safety America
1731 Roundrock Drive
Raleigh, NC 27615
P: (919) 872-3250
F: (919) 877-5775

Job Name : Oak Haven Lot 01 - RA1
Drawing : FP1
Location : 160 Oak Haven Drive
Remote Area : RA1
Contract : 21NC1513
Data File : RA1.WXF

HYDRAULIC CALCULATIONS
for

Project name: Oak Haven Lot 01

Location: 160 Oak Haven Drive

Drawing no: FP1

Date: 4/22/2021

Design

Remote area number: RA1

Remote area location: Master Bedroom

Occupancy classification: Residential

Density: .05 - Gpm/SqFt

Area of application: 230 - SqFt

Coverage per sprinkler: 400 - SqFt

Type of sprinklers calculated: VK494

No. of sprinklers calculated: 1

In-rack demand: N/A - GPM

Hose streams: 3 - GPM

Total water required (including hose streams): 23.03 - GPM @ 29.52 - Psi

Type of system: WET

Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 4/21/2021

Location: NC 42, NC 27540

Source: Fire & Life Safety America

Name of contractor: Fire & Life Safety America

Address: 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250

Phone number: F: (919) 877-57

Name of designer: H. WEYANT

Authority having jurisdiction: Harnett County

Notes: (Include peaking information or gridded systems here.)


Water Supply Curve C

Fire & Life Safety America
Oak Haven Lot 01 - RA1

Page 2
Date 4/22/2021

City Water Supply:
C1 - Static Pressure : 54.5
C2 - Residual Pressure: 13.5
C2 - Residual Flow : 417

Demand:
D1 - Elevation : 2.599
D2 - System Flow : 20.024
D2 - System Pressure : 29.526
Hose (Demand) : 3
D3 - System Demand : 23.024
Safety Margin : 24.782



Fittings Used Summary

Fire & Life Safety America
Oak Haven Lot 01 - RA1

Page 3
Date 4/22/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Fire & Life Safety America
Oak Haven Lot 01 - RA1

Page 4
Date 4/22/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.5	13.5	417.0	54.307	23.02	29.526

NODE ANALYSIS


<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S101	9.0	4.9	16.7	20.02	
101	10.0		17.32		
M101	10.0		18.16		
M102	10.0		19.28		
M103	10.0		20.77		
TOR	8.0		23.42		
BOR	3.0		26.61		
UG1	3.0		27.41	3.0	
UG2	-3.0		32.08		
UG3	-3.0		32.1		
TEST	3.0		29.53		

Final Calculations : Hazen-Williams

Fire & Life Safety America
Oak Haven Lot 01 - RA1

Page 5
Date 4/22/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S101 to 101	9 10	4.90	20.02	1	2N	14.0 0.0	1.500 14.000	150	16.700 -0.433			
			20.02	1.101		0.0	15.500	0.0682	1.057	Vel =	6.75	
			0.0									
101			20.02						17.324	K Factor =	4.81	
101 to M101	10 10		20.02	1	O	5.0 0.0	7.250 5.000	150	17.324 0.0			
			20.02	1.101		0.0	12.250	0.0682	0.835	Vel =	6.75	
			0.0									
M101			20.02						18.159	K Factor =	4.70	
M101 to M102	10 10		20.02	1	O	5.0 0.0	11.375 5.000	150	18.159 0.0			
			20.02	1.101		0.0	16.375	0.0682	1.117	Vel =	6.75	
M102 to M103	10 10		0.0	1	O	5.0 0.0	16.917 5.000	150	19.276 0.0			
			20.02	1.101		0.0	21.917	0.0682	1.494	Vel =	6.75	
M103 to TOR	10 8		0.0	1	2O	10.0 0.0	16.208 10.000	150	20.770 0.866			
			20.02	1.101		0.0	26.208	0.0682	1.788	Vel =	6.75	
			0.0									
TOR			20.02						23.424	K Factor =	4.14	
TOR to BOR	8 3		20.02	1	N	7.0 0.0	8.000 7.000	150	23.424 2.166			
			20.02	1.101		0.0	15.000	0.0681	1.022	Vel =	6.75	
BOR to UG1	3 3		0.0	1	2E	7.65 0.0	4.000 7.650	150	26.612 0.0			
			20.02	1.101		0.0	11.650	0.0682	0.795	Vel =	6.75	
UG1 to UG2	3 -3	H3	3.00	1.25	T 2E	9.523 9.523	55.000 19.046	150	27.407 2.599			
			23.02	1.394		0.0	74.046	0.0280	2.071	Vel =	4.84	
UG2 to UG3	-3 -3		0.0	6	2G 3E	9.25 64.749	937.417 95.581	150	32.077 0.0			
			23.02	6.09	2F	21.583	1032.998	0	0.022	Vel =	0.25	
UG3 to TEST	-3 3		0.0	6	T 2E	43.037 40.168	1000.000 87.509	140	32.099 -2.599			
			23.02	6.16	G	4.304	1087.509	0	0.026	Vel =	0.25	
			0.0									
TEST			23.02						29.526	K Factor =	4.24	



Hydraulic calculations using HydraCALC

Fire & Life Safety America
1731 Roundrock Drive
Raleigh, NC 27615
P: (919) 872-3250
F: (919) 877-5775

Job Name : Oak Haven Lot 06 - RA2
Drawing : FP1
Location : 160 Oak Haven Drive
Remote Area : RA2
Contract : 21NC1513
Data File : RA2.WXF

HYDRAULIC CALCULATIONS
for

Project name: Oak Haven Lot 01
Location: 160 Oak Haven Drive
Drawing no: FP1
Date: 4/22/2021

Design

Remote area number: RA2
Remote area location: KITCHEN/NOOK
Occupancy classification: Residential
Density: .05 - Gpm/SqFt
Area of application: 333 - SqFt
Coverage per sprinkler: 256 - SqFt
Type of sprinklers calculated: VK494
No. of sprinklers calculated: 2
In-rack demand: N/A - GPM
Hose streams: 3 - GPM
Total water required (including hose streams): 28.99 - GPM @ 23.86 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 4/21/2021
Location: NC 42, NC 27540
Source: Fire & Life Safety America

Name of contractor: Fire & Life Safety America
Address: 1731 Roundrock Drive / Raleigh, NC 27615 / P: (919) 872-3250
Phone number: F: (919) 877-57
Name of designer: H. WEYANT
Authority having jurisdiction: Harnett County
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve C

Fire & Life Safety America
Oak Haven Lot 06 - RA2

Page 2
Date 4/22/2021

City Water Supply:
C1 - Static Pressure : 54.5
C2 - Residual Pressure: 13.5
C2 - Residual Flow : 417

Demand:
D1 - Elevation : 2.599
D2 - System Flow : 25.993
D2 - System Pressure : 23.860
Hose (Demand) : 3
D3 - System Demand : 28.993
Safety Margin : 30.345



Fittings Used Summary

Fire & Life Safety America
Oak Haven Lot 06 - RA2

Page 3
Date 4/22/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Fire & Life Safety America
Oak Haven Lot 06 - RA2

Page 4
Date 4/22/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	54.5	13.5	417.0	54.204	28.99	23.86

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S201	9.0	4.9	7.0	12.96	
S202	9.0	4.9	7.07	13.03	
201	10.0		6.81		
202	10.0		6.88		
M201	10.0		7.09		
M102	10.0		8.88		
M103	10.0		11.3		
TOR	8.0		15.5		
BOR	3.0		19.33		
UG1	3.0		20.61	3.0	
UG2	-3.0		26.39		
UG3	-3.0		26.42		
TEST	3.0		23.86		

Final Calculations : Hazen-Williams

Fire & Life Safety America
Oak Haven Lot 06 - RA2

Page 5
Date 4/22/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S201 to 201	9 10	4.90	12.96 12.96	1 1.101	N 0.0	7.0 0.0 8.000	150 0.0305	7.000 -0.433 0.244		Vel = 4.37	
201			0.0 12.96					6.811		K Factor = 4.97	
S202 to 202	9 10	4.90	13.03 13.03	1 1.101	N 0.0	7.0 0.0 8.000	150 0.0308	7.070 -0.433 0.246		Vel = 4.39	
202			0.0 13.03					6.883		K Factor = 4.97	
201 to M201	10 10		12.96 12.96	1 1.101	O 0.0	5.0 0.0 9.208	150 0.0305	6.811 0.0 0.281		Vel = 4.37	
M201			0.0 12.96					7.092		K Factor = 4.87	
202 to M201	10 10		13.03 13.03	1 1.101		0.0 0.0 6.792	150 0.0308	6.883 0.0 0.209		Vel = 4.39	
M201			0.0 13.03					7.092		K Factor = 4.89	
M201 to M102	10 10		25.99 25.99	1 1.101	O 0.0	5.0 0.0 16.167	150 0.1105	7.092 0.0 1.786		Vel = 8.76	
M102 to M103	10 10		0.0 25.99	1 1.101	O 0.0	5.0 0.0 21.917	150 0.1105	8.878 0.0 2.422		Vel = 8.76	
M103 to TOR	10 8		0.0 25.99	1 1.101	2N 0.0	14.0 0.0 30.208	150 0.1105	11.300 0.866 3.338		Vel = 8.76	
TOR			0.0 25.99					15.504		K Factor = 6.60	
TOR to BOR	8 3		25.99 25.99	1 1.101	N 0.0	7.0 0.0 7.000	150 0.1105	15.504 2.166 1.657		Vel = 8.76	
BOR to UG1	3 3		0.0 25.99	1 1.101	2E 0.0	7.65 0.0 7.650	150 0.1105	19.327 0.0 1.287		Vel = 8.76	
UG1 to UG2	3 -3	H3	3.00 28.99	1.25 1.394	T 2E 0.0	9.523 9.523 74.046	150 0.0429	20.614 2.599 3.173		Vel = 6.09	
UG2 to UG3	-3 -3		0.0 28.99	6 6.09	2G 3E 2F	9.25 64.749 21.583	150 0	937.417 95.581 1032.998		Vel = 0.32	
UG3 to TEST	-3 3		0.0 28.99	6 6.16	T 2E G	43.037 40.168 4.304	1000.000 87.509 1087.509	140 -2.599 0		Vel = 0.31	
TEST			0.0 28.99					23.860		K Factor = 5.93	

Final Calculations : Hazen-Williams

Fire & Life Safety America
Oak Haven Lot 06 - RA2

Page 6
Date 4/22/2021

Node1	Elev1	K	Qa	Nom	Fitting		Pipe	CFact	Pt			
to					or		Ftngs		Pe	*****	Notes	*****
Node2	Elev2	Fact	Qt	Act	Equiv	Len	Total	Pf/Ft	Pf			
