
Harnett County Department of Public Health

Improvement Permit

Α.	building permit cannot be issued with only an Improvement	Permit	
11. Homes	PROPERTY LOCATION: 108 seaso	on Dr	
ISSUED TO: Adams Homes	SUBDIVISION Carolina Seasons		
NEW X REPAIR (39'x 39') Type of Structure: SFR	Site Improvements requ	vired prior to Construction Authorization Issuance:	
Proposed Wastewater System Type: Pump to 50			
Projected Daily Claws 480 GPD			
Number of bedrooms: 4 Number of Occupa	ants:8max		
Basement Yes Mo	nic.		
	red based on final location and elevations of facilities		
	Well Distance from well	Permit valid for: Five years	
W - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	- Frem Distance nom nen	☐ No expiration	
Permit conditions:			
Australia Come Amore Male / Man	REHS Date: 11-20-2020	SEE ATTACHED SITE SKETCH	
The insurance of this parmit by the Health Department in on way quaran	tees the issuance of other permits. The permit holder is responsible for the	king with appropriate governing bodies in meeting their requirements. This	
site is subject to revocation if the site plan, plat, or the intended use cl	hanges. The Improvement Permit shall not be affected by a change in owner	ship of the site. This permit is subject to compliance with the provisions of	
the Laws and Rules for Sewage Treatment and Disposal and to condition	s of this permit.		
	Construction Authorization		
	(Required for Building Permit)		
The construction and installation requirements of Rules .1950, .1952, .15	9541955, .1956, .1957, .1958. and .1959 are incorporated by references i	into this permit and shall be met. Systems shall be installed in accordance	
with the attached system layout.			
ISSUED TO: Adams Homes	PROPERTY LOCATION: 108 S	Season Dr	
ISSUED TO: HOLDER FIRMES		easons LOT # 109	
(20' × 20')		easons	
Facility Type: SFR (39'x39')	New □ Expansion □ Repair		
Basement? Yes X No Basement Fixt	tures? 🔲 Yes 🔀 No	(180	
Type of Wastewater System** Pump to 50	% reduction	(Initial) Wastewater Flow: 480 GPD	
(See note below, if applicable)			
Pump to	reduction (Repair)		
Installation Requirements/Conditions	Number of trenches 3		
	Exact length of each trench 60 feet	Trench Spacing: 9 Feet on Center	
Septic Tank Size 1000 gallons		Soil Cover: 6 inches	
Pump Tank Size 1000 gallons	Trenches shall be installed on contour at a	7011 CUTCH G	
	Maximum Trench Depth of: 18-28 inches	(Maximum soil cover shall not exceed	
	(Trench bottoms shall be level to +/-1/4"	36" above the trench bottom)	
	in all directions)		
Pump Requirements:ft. TDH vs	GPM	inches below pipe	
Tomp negativeness.		Aggregate Depth: inches above pipe	
		12 inches total	
Conditions:			
WATER LINES (INCLUDING IRRIGATION) MUST B	BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR R	REPAIR AREA.	
NO UTILITIES ALLOWED IN INITIAL OR REPAIR D	IRAIN FIELD AREA.		
BESTEVEN PERMITS AND ACCOUNTS AS A STATE OF THE PERMITS AS A STATE OF		- Committee of the same	
**If applicable: 1 understand the system type specified	is different from the type specified on the application.	I accept the specifications of this permit.	
Owner/Legal Representative Signature:		Date:	
This Construction Authorization is subject to revocation if the site plan,	plat, or the intended use changes. The Construction Authorization shall not b	be transferred when there is a change in ownership of the site. This	
Construction Authorization is subject to compliance with the provisions of	f the Laws and Rules for Sewage Treatment and Disposal and to the condition	ons of this permit. SEE ATTACHED SITE SKETCH	
Authorized State Agent: Mad	Date	11-20-2020	
AUTHORIZED STATE Agent.	Construction Authorization Expiration D		
	Construction Authorization Expiration D	ate. 11-20-25	

Harnett County Department of Public Health Site Sketch

Property Location: 108 Sea	isons Dr			
Issued To: Adams	Homes	Subdivision Carolina Seasons		Lot # <u>109</u>
Authorized State Agent: Mal Managers			Date: 11-20-2020	



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.