Harnett County Department of Public Health

Improvement Permit


A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 108 season Dr LOT # 109 _ subdivision Carolina Seasons ISSUED TO: MRH Land Holding Site Improvements required prior to Construction Authorization Issuance: NEW 🔀 EXPANSION: Type of Structure: SFR Proposed Wastewater System Type: Pump to 25% reduction Projected Daily Flow: 360 Number of Occupants: 6 Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities Pump Required: XYes No Five years Permit valid for: Type of Water Supply: Community No expiration Permit conditions: Authorized State Agent:

Date: 11-20-2020 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This Date: 11-20-2020 site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958 and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 108 Season Dr ISSUED TO: MRH Land Holding LOT # 109 SUBDIVISION Carolina Seasons Facility Type: SFR Expansion Repair ✓ New Basement? Yes Basement Fixtures? Yes ⊠ No Pump to 25% reduction (Initial) Wastewater Flow: 360 GPD Type of Wastewater System** (See note below, if applicable) Pump to 25% or 50% reduction (Repair) Number of trenches 3 Installation Requirements/Conditions Trench Spacing: 9 Feet on Center Exact length of each trench 60 Septic Tank Size 1000 gallons Pump Tank Size 1000 Soil Cover: 6 inches Trenches shall be installed on contour at a ____gallons Maximum Trench Depth of: 18-28 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) inches below pipe Pump Requirements: ft. TDH vs. _____ inches above pipe Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **|| applicable: | understand the system type specified is different from the type specified on the application. | accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Mak the RENT Date: 11-20-2020 Construction Authorization Expiration Date: 11-20-25

Harnett County Department of Public Health Site Sketch

Property Location: 108 Sea	sons Dr		
Issued To: MRH Land Holdin	g Subdivision Carolina Seasons		Lot # 109
Authorized State Agent:	Mal At acts	Date:	11-20-2020



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.