Fleet Temple, P.E.

Jason E Godwin , P.L.S.



Email: general@enochengineers.com

www.enochengineers.com

MATERIALS & TEST DIVISION

FIELD REPORT

| PROJECT | | | | | |
|----------|------------------|--------------------------|--|--|--|
| CLIENT: | CUMBERLAND HOMES | DATE: 1.21.21 | | | |
| PROJECT: | SOUTH CREEK S/D | CONRACTOR: DENNIS NORRIS | | | |
| ADDRESS: | 123 HEATH DR | TECHNICIAN: BH | | | |
| LOT#: | 50 | | | | |

TEST SUMMARY

PERFORMED NDT ON STEMWALL SOIL BACKFILL AT SITE NOTED ABOVE USING A TARGET DENSITY OF 120 PCF.
SOILS CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

| SERVICE PERFORMED | TEST NO. | COMP % | WD PCF | DD PCF | MOISTURE % |
|----------------------|----------|--------|--------|--------|------------|
| NDT | 1 | 100+ | 120.2 | 123.5 | 2.8 |

| RETURN VISTI | REQUIRED? | CAR CULT |
|--------------|-----------|---|
| YES NO | | DE SESSION OF THE PROPERTY OF |
| TECHNICIAN: | Dis Dis | claimer: |

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 60 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying