## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 67 Heath Dr. (Neills Creek Road - SR 15 SUBDIVISION South Creek ISSUED TO: Cumberland Homes Inc. EXPANSION | Site Improvements required prior to Construction Authorization Issuance: REPAIR Type of Structure: 75x58 sfd, 3 beds 2 baths Proposed Wastewater System Type: 25% Reduction Sys. Projected Daily Flow: 360 GPD Number of Occupants: 6 Number of bedrooms: 3 Basement Yes X No May be required based on final location and elevations of facilities Pump Required: Yes Type of Water Supply: Community Public Well Distance from well feet Five years Permit valid for: No expiration Permit conditions: Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Cumberland Homes Inc. PROPERTY LOCATION: 67 Heath Dr. (Neills Creek Road) SUBDIVISION South Creek Facility Type: 75x58 sfd, 3 beds 2 baths New Expansion Basement Fixtures? Yes Basement? Yes No Type of Wastewater System\*\* 25% Reduction System (Initial) Wastewater Flow: 360 GPD (See note below, if applicable ) 25% Reduction System Number of trenches 4 Installation Requirements/Conditions Exact length of each trench 60 Septic Tank Size 1000 Trench Spacing: 9 Feet on Center Soil Cover 12 Pump Tank Size \_\_\_\_\_ Trenches shall be installed on contour at a gallons Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4' 36" above the trench bottom) in all directions) NA Pump Requirements: ft. TDH vs. inches below pipe Aggregate Depth: NA inches above pipe Conditions: Gravity to D-Box Equal Distribution NA inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: 

## Harnett County Department of Public Health Site Sketch

Prop	erty Location: 67 Heath Dr. (Neills C	Creek Road - SR 1513)	
	ed To: Cumberland Homes Inc.	Subdivision South Creek  ANDRES COLUMN	Lot #52 Date:11   25   2020
	(11)	OFT LINES ON FIVELS STALL BE NON ALOUND SEPTICE	DET LINES
		237	
4651	49 - CANTER 18827	1041  1050 1501 5  1070 1501 5  1070 1501 5  1070 1500 1500 1500 1500 1500 1500 1500	TION PH

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.