



FIELD REPORT

FOUNDATION DEPARTMENT

PROJECT NAME: <u>Garage Code</u>	PROJECT #: <u>69725</u>
PROJECT LOCATION: <u>Spring Lake, NC</u>	SUMMIT REPRESENTATIVE: <u>Alex</u>
DATE: <u>7/15/21</u>	PRESENT AT SITE:
CLIENT/CONTRACTOR: <u>Capitol (17)</u>	MILEAGE:
WORK PERFORMED: <u>Reconstruction</u>	TOTAL TIME:

AS REQUESTED, **SUMMIT** REPRESENTATIVE REPORTED TO THE ABOVE REFERENCED SITE TO EVALUATE NEAR SURFACE FOUNDATION BEARING MATERIALS FOR THE PROPOSED.

LOT/BUILDING NUMBER: 1164

ADDRESS:

PERMIT NUMBER:

OUR TESTING AND OBSERVATIONS INDICATE THAT THE SOILS TESTED BY **SUMMIT** (ARE / ARE NOT) SUITABLE FOR THE

MINIMUM ALLOWED BEARING CAPACITY OF 700 PSF AT THIS TIME.

ACTION REQUIRED:

SUMMIT Observed (OK)

RETURN VISIT REQUIRED: YES/NO NO SIGNED (SUMMIT) 

SIGNED (CLIENT/CONTRACTOR IF REQUIRED)

ENGINEERING • LABORATORY • TESTING

3070 HAMMOND BUSINESS PLACE • SUITE 171 • RALEIGH, NC 27603 • (919) 380-9991 • (919) 380-9993 (FAX)
WWW.SUMMIT-COMPANIES.COM