



Connector Information					Nail Information	
Sym	Product	Manuf	Qty	Supported Member	Header	Truss
	HUS26	USP	1	Varies	16d/3-1/2"	16d/3-1/2"
	THD410	USP	1	Varies	16d/3-1/2"	10d/3"

Dimension Notes

1. All exterior wall to wall dimensions are to face of sheathing unless noted otherwise

2. All interior wall dimensions are to face of frame wall unless noted otherwise

3. All exterior wall to truss dimensions are to face of frame wall unless noted otherwise

Roof Area = 4465.37 sq.ft. Ridge Line = 136.85 ft. Hip Line = 12.84 ft. Horiz. OH = 191.33 ft. Raked OH = 228.17 ft. Decking = 153 sheets

All Walls Shown Are Considered Load Bearing

= Indicates Left End of Truss(Reference Engineered Truss Drawing)Do Not Erect Trusses Backwards

WALL SCHEDULE				
1st Floor Brg. Wall				
Gar. Walls Dropped				
====⊐ Non-Bearing Walls				

ROOF & FLOOR TRUSSES & BEAMS

Reilly Road Industrial Park

Fayetteville, N.C. 28309 Phone: (910) 864-8787

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.
These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

pearing reactions less than or equal to 3000# are beened to comply with the prescriptive Code quirements. The contractor shall refer to the tached Tables ( derived from the prescriptive ode requirements ) to determine the minimum undation size and number of wood studs quired to support reactions greater than 3000# at not greater than 1500#. A registered design rofessional shall be retained to design the upport system for any reaction that exceeds ose specified in the attached Tables. A gistered design professional shall be retained to design the upport system for any reaction that exceeds

Sales Area

 JILDER
 Watermark Homes
 COUNTY
 Harnett County

 OB NAME
 Lot 19 Oak Haven
 ADDRESS
 Lot 19 Oak Haven

 AN
 Teh Shasta Fir III
 MODEL
 Roof

 EAL DATE
 5/26/17
 DATE REV.
 7/30/20

 UOTE #
 NA
 DRAWN BY
 Anthony Williams

 OB ##
 J0720-3457
 SALESMAN
 Anthony Williams

LOAD CHART FOR JACK STUDS

(BASED ON TABLES R502.5(1) & (b))

NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADER/GIRDER

Truss Placement Plan SCALE: 1/4" = 1'-0"