

SOUTHEASTERN SOIL & ENVIRONMENTAL ASSOC., INC.

PROPOSED SUBSURFACE WASTE DISPOSAL SYSTEM DETAIL SHEET

SUBDIVISION: Summerlin

LOT 403

INITIAL SYSTEM: ^{GRAV} APPROVED 25% REDUCTION

REPAIR ^{GRAV} APPROVED 25% Reduction

DISTRIBUTION: SERIAL

DISTRIBUTION SERIAL

BENCHMARK: 100.0

LOCATION BC Lot IRON 42/43

NO. BEDROOMS: 3

LIAR 0.4 gpd/ft²

LINE	FLAG COLOR	ELEVATION	LENGTH
1	W	107.41	40
2	B	106.83	60
3	W	106.33	50
4a	B	106.00	45
			225
4b	B	106.00	40
5	W	105.50	85
6	B	104.75	95
7	W	104.00	75
8	B	103.50	45
			330 AVAILABLE

BY B. C. Raynor

DATE 07/16/2018

TYPICAL PROFILE
0-14 LS v fri gran
14-36 s.c. Firm SBK
CR2 72"

THERE SHALL BE NO GRADING,
CUTTING, LOGGING OR OTHER SOIL
DISTURBANCE IN SEPTIC AREA

