Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 133 Old Buies Creek Road (SR 1542) BANEFOOT BUDG CO ISSUED TO: Southeastern Construction of B.C. SUBDIVISION C M Johnson Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 3-Bedroom 49x52 SFD Proposed Wastewater System Type: 25% Reduction System Projected Daily Flow: 360 Number of Occupants: 6 Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities ☐ No Pump Required: Yes Public Well Distance from well NA feet Permit valid for: X Five years Type of Water Supply:
Community No expiration Permit conditions: Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. BANEFOOT BUDG CO. ISSUED TO: Southeastern Construction of B.C. PROPERTY LOCATION: 133 Old Buies Creek Road (SR 1542) SUBDIVISION C M Johnson LOT # TR-D Facility Type: 3-Bedroom 49x52 SFD Expansion Basement Fixtures? Yes Basement? Yes No 2570 REDICTION STOTEM (Initial) Wastewater Flow: 360 Type of Wastewater System** (See note below, if applicable) Installation Requirements/Conditions Number of trenches Trench Spacing: Feet on Center Septic Tank Size 1000 gallons Exact length of each trench _ Soil Cover: Trenches shall be installed on contour at a Pump Tank Size Maximum Trench Depth of: (Maximum soil cover shall not exceed inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) inches below pipe Pump Requirements: ______ft. TDH vs. ___ inches above pipe Aggregate Depth: ~~ inches total Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Date: 90 12/09/2020 C9/15/2021 Authorized State Agent: ___ Construction Authorization Expiration Date 12/09/2025 04/15/2026 ANDLEW

Harnett County Department of Public Health Site Sketch

