Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

Sheet: Property ID: Lot #: File #:

Code:

SFD2012-0011

## SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: _ Applicant: >AVIT	+ KINDERLY MISKI EXXX		
Address: 1212 FE5705 15 I	Date Evaluated: 12/14/2020		
Proposed Facility:	Design Flow (.1949): 3606(0	Property Size:	
Location of Site:	Property Recorded:		_
Water Supply: Public	☐ Individual ☐ Well	Spring	Other
Evaluation Method Auger Boring	☐ Pit ☐ Cut		
Type of Wastewater: Sewag	e Industrial Process	☐ Mixed	
D			

P R O F I .1940 L Landscap E Position/ # Slope %	.1940	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
	Landscape Position/		.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
3,4	L 3-5%	0-36	GRAVELLY LUAMYSIND	EM NSM				ps	
		36-48	61/5CL	EM NSM		48			0.45

Description	Initial	Repair System	Other Factors (.1946):
•	System		Site Classification (.1948): [novisional Soitable
Available Space (.1945)			Evaluated By: Apprices comp, 12413
System Type(s)	25% 100	25% 100	Others Present:
Site LTAR	6.45	0.45	

COMMENTS: \_\_\_\_

LANDSCAPE POSITIONS	<u>GROUP</u>	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	Ш	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

IV SIC-SILTY CLAY 0.4 - 0.1

C-CLAY

SC-SANDY CLAY

**STRUCTURE** SG-SINGLE GRAIN M- MASSIVE CR-CRUMB

MINERALOGY

SLIGHTLY EXPANSIVE

EXPANSIVE

GR-GRANULAR

SBK-SUBANGULAR BLOCKY

