Harnett County Department of Public Health

Improvement Permit A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 101 Linda Lou Ln (Mitchell Rd. - SR 1535) ISSUED TO: A&G Residential LLC subdivision Mitchell Manor REPAIR 🗌 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 41x45 sfd, 4 beds 2.5 baths Proposed Wastewater System Type: 25% Reduction Sys. Projected Daily Flow: 480 Number of Occupants: 8 Number of bedrooms: 4 Basement Yes X No ☐ No May be required based on final location and elevations of facilities Pump Required: Yes Type of Water Supply: 🔲 Community 🗵 Public 🔲 Well Distance from well NA ______feet Permit valid for: X Five years ■ No expiration Permit conditions: Authorized State Agent:: / The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit... Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 101 Linda Lou Ln (Mitchell Rd. - SR 153) ISSUED TO: A&G Residential LLC SUBDIVISION Mitchell Manor Facility Type: 41x45 sfd, 4 beds 2.5 batl Expansion Basement Fixtures? Yes Basement? Yes 25% NESDOSION (Initial) Wastewater Flow: 480 GPD Type of Wastewater System** (See note below, if applicable) 25% LEDUCTION STSTEN Number of trenches 5 Installation Requirements/Conditions Trench Spacing: __ Feet on Center Exact length of each trench Septic Tank Size 1000 gallons Soit Cover: 🔙 Trenches shall be installed on contour at a Pump Tank Size _gallons Maximum Trench Depth of: ____ 24 (Maximum soil cover shall not exceed inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) NA Pump Requirements: ______ft. TDH vs. _____ ___ inches below pipe Aggregate Depth: NA ___inches above pipe NA inches total Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Construction Authorization Expiration Date: 01/07/2026

Authorized State Agent: ____

ANDREW WALLA

Harnett County Department of Public Health Site Sketch

Property Location: 101 Linda Lou Ln. (Mitchell Road - SR 1535) Subdivision Mitchell Manor Issued To: A&G Residential LLC Lot # 23 Authorized State Agent: CP 11.0

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.