
Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 6809 OLD US 421 ISSUED TO: Weaver Homes Inc. SUBDIVISION ByRd Farm NEW 🔯 REPAIR 🗍 EXPANSION | Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 41' x 60 SFD Proposed Wastewater System Type: 25% reduction Projected Daily Flow: 360 GPD Number of Occupants: 6 Number of bedrooms: 3_ Basement Yes Pump Required: Yes No May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well ______feet **☒** Five years Permit valid for: Permit conditions: ☐ No expiration Date: 02-10-21 REH The issuance of this permit by the fealth Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their sequirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1955, .1955, .1959, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layous. ISSUED TO: Weaver Homes Inc PROPERTY LOCATION: 6809 OLD US 421 SUBDIVISION. Facility Type: 41' x 60' SFD Expansion ⊠ No Basement? Yes Basement Fixtures? Tyes 冈No Type of Wastewater System** 25% reduction (Initial) Wastewater Flow: 360 (See note below, if applicable [1]) 25% reduction Installation Requirements/Conditions_ Number of trenches 4 Septic Tank Size 1000 gallons Exact length of each trench 75 Trench Spacing: 9 Feet on Center Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: 6 inches Maximum Trench Depth of: 18" inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. GPM _ inches: below_pipe Aggregate Depth: ______ inches above pipe inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. *If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: _ This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Date: 02-10-21 Construction Authorization Expiration Date: 02-10-26

Harnett County Department of Public Health Site Sketch



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.