



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

3/2/2022

SUBJECT: SFD2101-0024
SINGLE FAMILY DWELLING

To: FLOYD PROPERTIES AND DEV INC

Here are the results of all Inspections located at **211 EDUCATION DR:**

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: T-POLE
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: FINAL SFD CRAWL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: INSULATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time:
Completed Date/Time:
Inspector: EH Bucket
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 5/3/2021
Completed Date/Time: 5/3/2021
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time: 8/2/2021
Completed Date/Time: 8/2/2021
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time: 8/26/2021
Completed Date/Time: 8/26/2021
Inspector: CP Bucket
Result: APPROVED
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 9/7/2021
Completed Date/Time: 9/7/2021
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 11/8/2021
Completed Date/Time: 11/9/2021
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: HANGING OUTLET GOING IN MASTER BED, HEAD TEST DOWN, INSULATE AT BUILDERS DISCRETION

Inspection Type: ADDRESS
Scheduled Date/Time: 11/15/2021
Completed Date/Time: 11/15/2021
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 211 EDUCATION DR SPRING LAKE 28390.

Inspection Type: ROUGH IN
Scheduled Date/Time: 11/16/2021
Completed Date/Time: 11/16/2021
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: Need to pass insulation before signing off on rough in



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 11/16/2021
Completed Date/Time: 11/16/2021
Inspector: Slade Burton Lawson III
Result: DISAPPROVED
Remarks:
Notes: Secure insulation above F/P

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 2/15/2022
Completed Date/Time: 2/15/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 2/15/2022
Completed Date/Time: 2/15/2022
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 2/28/2022
Completed Date/Time: 2/28/2022
Inspector: Slade Burton Lawson III
Result: APPROVED W/EXC
Remarks: eTRAKiT Inspection Request
Notes: 2/24/2022 11:42 AM Floyd Properties Development

Contact Name: Floyd Properties Development
Site Address: 211 EDUCATION DR
Phone: 9102375008
e-Mail: jrichard6@nc.rr.com

Check air handler at final