## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 5995 Rosser Pittman Rd (SR1215) ISSUED TO: Landry Builders SUBDIVISION REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 48' x 48' SFD Proposed Wastewater System Type: 25% reduction Projected Daily Flow: 480 Number of bedrooms: 4 Number of Occupants: 8 Basement Yes May be required based on final location and elevations of facilities ☐ No Pump Required: Yes Type of Water Supply: Community Public Well Distance from well \_\_\_\_\_\_\_feet X Five years Permit valid for: No expiration Permit conditions: Authorized State Agent:: Date: 3-16-21 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This REHS Date: 3-16-21 SEE ATTACHED SITE SKETCH site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 5995 Rosser Pittman Rd (SR1215) ISSUED TO: Landry Builders SUBDIVISION Facility Type: 48' x 48' SFD Expansion Repair Basement Fixtures? Yes Basement? Yes × No × No Type of Wastewater System\*\* 25% reduction (Initial) Wastewater Flow: 480 GPD (See note below, if applicable ) 25% reduction Number of trenches 4 Installation Requirements/Conditions \_feet Trench Spacing: 9 Feet on Center Exact length of each trench 75 Septic Tank Size 1000 gallons Soil Cover: 6 inches Trenches shall be installed on contour at a gallons Pump Tank Size \_\_\_\_\_ Maximum Trench Depth of: 22" inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) inches below pipe Conditions: IF proper fall to Septic Tank Can Not be obtained by Gravity. \_\_\_\_\_ inches total Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_ WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Mah M Date: 3-16-21 Construction Authorization Expiration Date: 3-16-26

## Harnett County Department of Public Health Site Sketch

roperty Location: 5995 Rosse	ar Fillinan Rd (SR1213)	1 04 #
sued To: Landry Builders	Subdivision	Lot #
uthorized State Agent:	al R-REHS	Date: 3-16-21
(		
	0	
	wood sel	
	00	
	FUTURE 10' 25% ! 10' 18' 18' 18' 18' 18' 18' 18' 18' 18' 18'	
	10' 25% 1 UBT Home	
	1 Repair 1	
	1 Area	
	75 110	
	75'	
	75' Driveway	× -
	\$ 12'	

Rosser Pittman Rd (SR 1215)

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.