

# Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: STEPHENSON BLDG INC. PROPERTY LOCATION: 84 SIMPLY COUNTRY LN. (US 401 N.)  
 SUBDIVISION: MORGAN FARM LOT # 26  
 NEW  REPAIR  EXPANSION   
 Type of Structure: 3-BR 58'x54' SFD  
 Proposed Wastewater System Type: 25% REDUCTION SIS.  
 Projected Daily Flow: 360 GPD  
 Number of bedrooms: 3 Number of Occupants: 6 max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well NA feet  
 Permit valid for:  Five years  No expiration  
 Permit conditions: \_\_\_\_\_

Authorized State Agent: [Signature] Date: 02/26/2021 <sup>06/10/2021</sup> SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization (Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: STEPHENSON BLDG INC. PROPERTY LOCATION: 84 SIMPLY COUNTRY LN. (US 401 N.)  
 SUBDIVISION: MORGAN FARM LOT # 26  
 Facility Type: 3-BR 58'x54' SFD  New  Expansion  Repair  
 Basement?  Yes  No  Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* AT-GRADE 25% REDUCTION SIS. (Initial) Wastewater Flow: 360 GPD  
 (See note below, if applicable   
AT-GRADE 25% REDUCTION (Repair)

**Installation Requirements/Conditions**  
 Septic Tank Size 1000 gallons  
 Pump Tank Size \_\_\_\_\_ gallons  
 Number of trenches 3  
 Exact length of each trench 75 feet  
 Trenches shall be installed on contour at a Maximum Trench Depth of: 42-1/2 inches (Trench bottoms shall be level to +/- 1/4" in all directions)  
 Trench Spacing: 9 Feet on Center  
 Soil Cover: 6 inches (Maximum soil cover shall not exceed 36" above the trench bottom)  
 Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM  
 Aggregate Depth: NA inches below pipe NA inches above pipe  
 Conditions: PUMP TO MEDIUM D-BOX w/ EQUAL DISTRIBUTION REQUIRED NA inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 02/26/2021 <sup>06/10/2021</sup>  
ANDREW COLLIN Construction Authorization Expiration Date: 02/26/2026 <sup>06/10/2026</sup>


Application # SI-DR/02-0007

# Harnett County Department of Public Health Site Sketch

Property Location: 84 SIMPLY COUNTRY LN. (US 401 N.)

Issued To: STEPHENSON BUS BROS. Subdivision MORGAN FARM Lot # 26

Authorized State Agent: *Andrew G. Quinn* Date: 06/10/2021  
ANDREW QUINN 02/26/2021



- \* PUMP TO MEDIUM D-BOX  
EQUAL DISTRIBUTION
- \* STS, FLAGGED ON SITE
- \* EVAL/ PERMIT UNDER  
ABNORMAL WET CONDITIONS
- ↳ AT-GRADE INSTALL W/ IMPORT  
FILL REQUIRED [6IN MAX]
- OR  
ALLOW TO REVEL @ INSTALL  
FOR ADDITIONAL DEPTH AND/OR  
COURTIN DRAIN MAY BE  
REQUIRED
- \* EVAL UNDER DRY CONDITIONS  
NO FILL REQUIRED  
@ 18IN  
[06/10/2021]

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.