


| | | | |
|-------------------|-----------------------------|-------------------|----------------------------------|
| DATE: | 4/12/2021 | COMPANY: | Schumacher Homes |
| VITRUVIUS BUILD: | StruCalc | DESIGNED BY: | Dan Fishtorn |
| CUSTOMER: | Taylor DU700 021 0807 | REVIEWED BY: | Dan Fishtorn |
| PROJ. ADDRESS: | | PROJECT NAME: | Taylor DU700 021 0807 |
| LEVEL: | Main Floor | LOADING: | LRFD |
| MEMBER NAME: | Garage Door Header | CODE: | 2018 International Building Code |
| MEMBER TYPE: | FLOOR BEAM | NDS: | 2018 NDS |
| MATERIAL: | STRUCTURAL COMPOSITE LUMBER | | |
| Louisiana Pacific | 2.0E LVL | (2) 1.75 X 11.875 | DRY |

Garage Door Header DIAGRAM



BEAM PROPERTIES

Start (ft): 0 End (ft): 16 Member Slope: 0/12 Actual Length (ft): 16

| Area | Ix | Iy | BSW | Lams | Cfn | Kcr |
|--------------------|--------------------|--------------------|----------|------|-----|--------------|
| (in ²) | (in ⁴) | (in ⁴) | (lbf/ft) | | | Creep Factor |
| 41.56 | 488.41 | 10.61 | 11.83 | 2 | 9 | 1 |

STRENGTH PROPERTIES

| | Fb (psi) | Ft (psi) | Fv (psi) | Fc (psi) | Fc⊥ (psi) | E (psi) x10 ³ | Emin (psi) x10 ³ |
|-------------------|----------|----------|----------|----------|-----------|--------------------------|-----------------------------|
| Base Values | 2900 | 1800 | 285 | 3200 | 750 | 2000 | 1000 |
| Adjusted Values | 6261 | 3888 | 616 | 6912 | 1127 | 2000 | 1496 |
| K _F *φ | 2.16 | 2.16 | 2.16 | 2.16 | 1.5 | 1 | 1.5 |
| C _M | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| C _T | 1 | 1 | 1 | 1 | 1 | 1 | 1 |

Bending Adjustment Factors C_V = 1 C_r = 1 Volume factor Is applied on a load combination basis And Is Not reflected in the adjusted values

BEAM DATA

| Span | Length (ft) | Unbraced Length (ft) | | Beam End | | | | |
|------|-------------|----------------------|--------|-----------------|---------|------------|----------|-----------|
| | | Top | Bottom | Elev. Diff (ft) | CL(Top) | CL(Bottom) | CL(Left) | CL(Right) |
| 1 | 16 | 0 | 16 | 0 | 1.00 | 0.29 | 1.00 | 1.00 |

PASS-FAIL

| | PASS/FAIL | MAGNITUDE | STRENGTH | LOCATION (ft) | LOAD COMBO | TIME EFFECT λ |
|------------------------|--------------|----------------|----------------|---------------|-----------------|---------------|
| Shear Stress Y (psi) | PASS (88.6%) | 56.1 | 492.5 | 0 | 1.2D+1.6L+0.5Lr | 0.8 |
| Bending Stress Y (psi) | PASS (81.9%) | 906.6 | 5014.7 | 8 | 1.2D+1.6L+0.5Lr | 0.8 |
| Deflection (in) | PASS (61.0%) | 0.208 (=L/923) | 0.533 (=L/360) | 8 | D+L | |
| Bearing Stress (psi) | PASS (92.8%) | 80.7 | 1127.3 | 0 | 1.2D+1.6L+0.5Lr | 0.8 |

REACTIONS

Units for V: lbf Units for M: lbf-ft

| Y axis | DEAD | LIVE | LIVE ROOF | SNOW | WIND + | WIND - | SEISMIC + | SEISMIC - | ICE | RAIN | EARTH |
|--------|------|------|-----------|------|--------|--------|-----------|-----------|-----|------|-------|
| A | 527 | 576 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| B | 527 | 576 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Reaction Location

A

B

LOAD LIST

| Type | Left Magnitude | Right Magnitude | Load Start (ft) | Load End (ft) | Load Type | Direction |
|----------------------|----------------|-----------------|-----------------|---------------|-----------|-----------|
| Uniform (lbf/ft) | 72 | 72 | 0 | 16 | Live | Y |
| Uniform (lbf/ft) | 54 | 54 | 0 | 16 | Dead | Y |
| Self Weight (lbf/ft) | 11.83 | 11.83 | 0 | 16 | Dead | Y |



| | | | |
|-------------------|-----------------------------|-----------------|----------------------------------|
| DATE: | 4/12/2021 | COMPANY: | Schumacher Homes |
| VITRUVIUS BUILD: | StruCalc | DESIGNED BY: | Dan Fishtorn |
| CUSTOMER: | Taylor DU700 021 0807 | REVIEWED BY: | Dan Fishtorn |
| PROJ. ADDRESS: | | PROJECT NAME: | Taylor DU700 021 0807 |
| LEVEL: | Main Floor | LOADING: | LRFD |
| MEMBER NAME: | Rear Foyer Beam in floor | CODE: | 2018 International Building Code |
| MEMBER TYPE: | FLOOR BEAM | NDS: | 2018 NDS |
| MATERIAL: | STRUCTURAL COMPOSITE LUMBER | | |
| Louisiana Pacific | 2.0E LVL | (2) 1.75 X 9.25 | DRY |

Rear Foyer Beam in floor DIAGRAM



BEAM PROPERTIES

Start (ft): 0 End (ft): 7.5 Member Slope: 0/12 Actual Length (ft): 7.5

| Area | I _x | I _y | BSW | Lams | C _{fn} | K _{cr} |
|--------------------|--------------------|--------------------|----------|------|-----------------|-----------------|
| (in ²) | (in ⁴) | (in ⁴) | (lbf/ft) | | | Creep Factor |
| 32.38 | 230.84 | 8.26 | 9.22 | 2 | 9 | 1 |

STRENGTH PROPERTIES

| | F _b (psi) | F _t (psi) | F _v (psi) | F _c (psi) | F _{c⊥} (psi) | E (psi) x10 ³ | E _{min} (psi) x10 ³ |
|----------------------------|---|----------------------|----------------------|----------------------|-----------------------|--------------------------|---|
| Base Values | 2900 | 1800 | 285 | 3200 | 750 | 2000 | 1000 |
| Adjusted Values | 6261 | 3888 | 616 | 6912 | 1127 | 2000 | 1496 |
| K _F *φ | 2.16 | 2.16 | 2.16 | 2.16 | 1.5 | 1 | 1.5 |
| C _M | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| C _T | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| Bending Adjustment Factors | C _V = 1.03 C _r = 1 Volume factor Is applied on a load combination basis And Is Not reflected in the adjusted values | | | | | | |

BEAM DATA

| Span | Length (ft) | Unbraced Length (ft) | | Beam End | | | | |
|------|-------------|----------------------|--------|-----------------|---------|------------|----------|-----------|
| | | Top | Bottom | Elev. Diff (ft) | CL(Top) | CL(Bottom) | CL(Left) | CL(Right) |
| 1 | 7.5 | 0 | 7.5 | 0 | 1.00 | 0.72 | 1.00 | 1.00 |

PASS-FAIL

| | PASS/FAIL | MAGNITUDE | STRENGTH | LOCATION (ft) | LOAD COMBO | TIME EFFECT λ |
|------------------------|---------------------|-----------------|----------------|---------------|-----------------|---------------|
| Shear Stress Y (psi) | PASS (78.2%) | 107.6 | 492.5 | 7.5 | 1.2D+1.6L+0.5Lr | 0.8 |
| Bending Stress Y (psi) | PASS (79.7%) | 1046.5 | 5155.8 | 3.75 | 1.2D+1.6L+0.5Lr | 0.8 |
| Deflection (in) | PASS (73.7%) | 0.049 (=L/1826) | 0.188 (=L/480) | 3.75 | L | |
| Bearing Stress (psi) | PASS (89.3%) | 120.6 | 1127.3 | 0 | 1.2D+1.6L+0.5Lr | 0.8 |

REACTIONS

Units for V: lbf Units for M: lbf-ft

| Y axis | DEAD | LIVE | LIVE ROOF | SNOW | WIND + | WIND - | SEISMIC + | SEISMIC - | ICE | RAIN | EARTH |
|--------|------|------|-----------|------|--------|--------|-----------|-----------|-----|------|-------|
| A | 335 | 1200 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| B | 335 | 1200 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Reaction Location

A

B

LOAD LIST

| Type | Left Magnitude | Right Magnitude | Load Start (ft) | Load End (ft) | Load Type | Direction |
|---------------------|----------------|-----------------|-----------------|---------------|-----------|-----------|
| Uniform (lb/ft) | 320 | 320 | 0 | 7.5 | Live | Y |
| Uniform (lb/ft) | 80 | 80 | 0 | 7.5 | Dead | Y |
| Self Weight (lb/ft) | 9.22 | 9.22 | 0 | 7.5 | Dead | Y |

PASS

| | | | |
|-------------------|-----------------------------|-----------------|----------------------------------|
| DATE: | 4/12/2021 | COMPANY: | Schumacher Homes |
| VITRUVIUS BUILD: | StruCalc | DESIGNED BY: | Dan Fishtorn |
| CUSTOMER: | Taylor DU700 021 0807 | REVIEWED BY: | Dan Fishtorn |
| PROJ. ADDRESS: | | PROJECT NAME: | Taylor DU700 021 0807 |
| LEVEL: | Main Floor | LOADING: | LRFD |
| MEMBER NAME: | Beam over kitchen | CODE: | 2018 International Building Code |
| MEMBER TYPE: | FLOOR BEAM | NDS: | 2018 NDS |
| MATERIAL: | STRUCTURAL COMPOSITE LUMBER | | |
| Louisiana Pacific | 2.0E LVL | (2) 1.75 X 9.25 | DRY |

Beam over kitchen DIAGRAM



BEAM PROPERTIES

Start (ft): 0 End (ft): 6.09 Member Slope: 0/12 Actual Length (ft): 6.09

| Area | Ix | Iy | BSW | Lams | Cfn | Kcr |
|--------------------|--------------------|--------------------|----------|------|-----|--------------|
| (in ²) | (in ⁴) | (in ⁴) | (lbf/ft) | | | Creep Factor |
| 32.38 | 230.84 | 8.26 | 9.22 | 2 | 9 | 1 |

STRENGTH PROPERTIES

| | Fb (psi) | Ft (psi) | Fv (psi) | Fc (psi) | Fc _⊥ (psi) | E (psi) x10 ³ | Emin (psi) x10 ³ |
|----------------------------|---|----------|----------|----------|-----------------------|--------------------------|-----------------------------|
| Base Values | 2900 | 1800 | 285 | 3200 | 750 | 2000 | 1000 |
| Adjusted Values | 6261 | 3888 | 616 | 6912 | 1127 | 2000 | 1496 |
| K _F *φ | 2.16 | 2.16 | 2.16 | 2.16 | 1.5 | 1 | 1.5 |
| C _M | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| C _T | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| Bending Adjustment Factors | C _V = 1.03 C _r = 1 Volume factor Is applied on a load combination basis And Is Not reflected in the adjusted values | | | | | | |

BEAM DATA

| Span | Length (ft) | Unbraced Length (ft) | | Beam End | | | | |
|------|-------------|----------------------|--------|-----------------|---------|------------|----------|-----------|
| | | Top | Bottom | Elev. Diff (ft) | CL(Top) | CL(Bottom) | CL(Left) | CL(Right) |
| 1 | 6.09 | 0 | 6.09 | 0 | 1.00 | 0.82 | 1.00 | 1.00 |

PASS-FAIL

| | PASS/FAIL | MAGNITUDE | STRENGTH | LOCATION (ft) | LOAD COMBO | TIME EFFECT λ |
|------------------------|---------------------|-----------------|----------------|---------------|-----------------|---------------|
| Shear Stress Y (psi) | PASS (71.4%) | 140.9 | 492.5 | 0 | 1.2D+1.6L+0.5Lr | 0.8 |
| Bending Stress Y (psi) | PASS (78.4%) | 1113.6 | 5155.8 | 3.05 | 1.2D+1.6L+0.5Lr | 0.8 |
| Deflection (in) | PASS (77.1%) | 0.035 (=L/2095) | 0.152 (=L/480) | 3.05 | L | |
| Bearing Stress (psi) | PASS (86.0%) | 158.0 | 1127.3 | 0 | 1.2D+1.6L+0.5Lr | 0.8 |

REACTIONS

Units for V: lbf Units for M: lbf-ft

| Y axis | DEAD | LIVE | LIVE ROOF | SNOW | WIND + | WIND - | SEISMIC + | SEISMIC - | ICE | RAIN | EARTH |
|--------|------|------|-----------|------|--------|--------|-----------|-----------|-----|------|-------|
| A | 424 | 1583 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| B | 424 | 1583 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Reaction Location

A

B

LOAD LIST

| Type | Left Magnitude | Right Magnitude | Load Start (ft) | Load End (ft) | Load Type | Direction |
|---------------------|----------------|-----------------|-----------------|---------------|-----------|-----------|
| Uniform (lb/ft) | 520 | 520 | 0 | 6.08 | Live | Y |
| Uniform (lb/ft) | 130 | 130 | 0 | 6.08 | Dead | Y |
| Self Weight (lb/ft) | 9.22 | 9.22 | 0 | 6.09 | Dead | Y |

PASS

| | | | |
|-------------------|-----------------------------|-----------------|----------------------------------|
| DATE: | 4/12/2021 | COMPANY: | Schumacher Homes |
| VITRUVIUS BUILD: | StruCalc | DESIGNED BY: | Dan Fishtorn |
| CUSTOMER: | Taylor DU700 021 0807 | REVIEWED BY: | Dan Fishtorn |
| PROJ. ADDRESS: | | PROJECT NAME: | Taylor DU700 021 0807 |
| LEVEL: | Main Floor | LOADING: | LRFD |
| MEMBER NAME: | Left beam over foyer | CODE: | 2018 International Building Code |
| MEMBER TYPE: | FLOOR BEAM | NDS: | 2018 NDS |
| MATERIAL: | STRUCTURAL COMPOSITE LUMBER | | |
| Louisiana Pacific | 2.0E LVL | (2) 1.75 X 9.25 | DRY |

Left beam over foyer DIAGRAM



BEAM PROPERTIES

Start (ft): 0 End (ft): 6 Member Slope: 0/12 Actual Length (ft): 6

| Area | Ix | Iy | BSW | Lams | Cfn | Kcr |
|--------------------|--------------------|--------------------|----------|------|-----|--------------|
| (in ²) | (in ⁴) | (in ⁴) | (lbf/ft) | | | Creep Factor |
| 32.38 | 230.84 | 8.26 | 9.22 | 2 | 9 | 1 |

STRENGTH PROPERTIES

| | Fb (psi) | Ft (psi) | Fv (psi) | Fc (psi) | Fc _⊥ (psi) | E (psi) x10 ³ | Emin (psi) x10 ³ |
|----------------------------|---|----------|----------|----------|-----------------------|--------------------------|-----------------------------|
| Base Values | 2900 | 1800 | 285 | 3200 | 750 | 2000 | 1000 |
| Adjusted Values | 6261 | 3888 | 616 | 6912 | 1127 | 2000 | 1496 |
| K _F *φ | 2.16 | 2.16 | 2.16 | 2.16 | 1.5 | 1 | 1.5 |
| C _M | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| C _T | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| Bending Adjustment Factors | C _V = 1.03 C _r = 1 Volume factor is applied on a load combination basis And is Not reflected in the adjusted values | | | | | | |

BEAM DATA

| Span | Length (ft) | Unbraced Length (ft) | | Beam End | | | | |
|------|-------------|----------------------|--------|-----------------|---------|------------|----------|-----------|
| | | Top | Bottom | Elev. Diff (ft) | CL(Top) | CL(Bottom) | CL(Left) | CL(Right) |
| 1 | 6 | 0 | 6 | 0 | 1.00 | 0.90 | 1.00 | 1.00 |

PASS-FAIL

| | PASS/FAIL | MAGNITUDE | STRENGTH | LOCATION (ft) | LOAD COMBO | TIME EFFECT λ |
|------------------------|---------------------|-----------------|----------------|---------------|-----------------|---------------|
| Shear Stress Y (psi) | PASS (19.9%) | 394.5 | 492.5 | 0 | 1.2D+1.6L+0.5Lr | 0.8 |
| Bending Stress Y (psi) | PASS (60.6%) | 2030.1 | 5155.8 | 1.02 | 1.2D+1.6L+0.5Lr | 0.8 |
| Deflection (in) | PASS (69.1%) | 0.062 (=L/1165) | 0.200 (=L/360) | 2.64 | D+L | |
| Bearing Stress (psi) | PASS (60.8%) | 442.3 | 1127.3 | 0 | 1.2D+1.6L+0.5Lr | 0.8 |

REACTIONS

Units for V: lbf Units for M: lbf-ft

| Y axis | DEAD | LIVE | LIVE ROOF | SNOW | WIND + | WIND - | SEISMIC + | SEISMIC - | ICE | RAIN | EARTH |
|--------|------|------|-----------|------|--------|--------|-----------|-----------|-----|------|-------|
| A | 2697 | 3299 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| B | 705 | 660 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Reaction Location

A

B

LOAD LIST

| Type | Left Magnitude | Right Magnitude | Load Start (ft) | Load End (ft) | Load Type | Direction |
|---------------------|----------------|-----------------|-----------------|---------------|-----------|-----------|
| Uniform (lb/ft) | 60 | 60 | 0 | 6 | Dead | Y |
| Point (lb) | 3959 | - | 1 | - | Live | Y |
| Point (lb) | 2987 | - | 1 | - | Dead | Y |
| Self Weight (lb/ft) | 9.22 | 9.22 | 0 | 6 | Dead | Y |