

Highland Grove 4-Bedroom Septic Proposal Lot #3

System: Gravity to D-Box.
 Lines: 1-4 (300')
 0.4 LTAR
 24" Trench Bottom
 Accepted Status System
 System: Pressure Manifold.
 Lines: 5-9 (200')
 0.4 LTAR
 24" Trench Bottom
 T&J Panel System - 50% Reduction

GRAPHIC SCALE
 1" = 50'




3

48,325 SQ.FT.

20' PUBLIC DRAINAGE
 EASEMENT

- #4 Yellow 50'
- #3 Pink 50'
- #2 Blue 100'
- #1 Red 100'



- #9 Orange 50'
- #8 Red 50'
- #7 Yellow 50'
- #6 White 45'
- #5 Pink 40'

Windy Farm Drive

*If plumbing is not sufficient
 a seperate pump and tank may
 be required.

This drawing represents a
 preliminary septic plan made prior
 to final construction activities.
 A revised plan may need to be
 reworked at time of permitting.

Adams
 Soil Consulting
 919-414-6761
 Job #561

