Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 10425 McDougald Rd (SR1229) ISSUED TO: Andrew Buie SUBDIVISION REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 73' x 59' SFD Proposed Wastewater System Type: 25% reduction Projected Daily Flow: 600 Number of Occupants: 10 max Number of bedrooms: 5 Basement Yes Pump Required: Yes ☐ No May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well ______feet Permit valid for: X Five years ■ No expiration Permit conditions: Date: 3-16-21 SEE ATTACHED SITE SKETCH Authorized State Agent: Date: 3-16-21 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958 and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Andrew Buie PROPERTY LOCATION: 10425 McDougald Rd (SR1229) Facility Type: 73' x 59' SFD X New Expansion Basement? Yes × No Basement Fixtures? Yes X No 25% reduction Type of Wastewater System** (Initial) Wastewater Flow: 600 (See note below, if applicable) Pump to 25% reduction Number of trenches 4 Installation Requirements/Conditions Septic Tank Size 1250 gallons Exact length of each trench 94 Trench Spacing: 9 Feet on Center Trenches shall be installed on contour at a Soil Cover: 6 Pump Tank Size _____ gallons inches Maximum Trench Depth of: 18" - 24" inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. __ inches below pipe Aggregate Depth: inches above pipe inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Date: 3-16-21

Construction Authorization Expiration Date: 3-16-26

Authorized State Agent: Mah M

Harnett County Department of Public Health Site Sketch

Property Location: 10425 McDougald Rollssued To: Andrew Buie	Subdivision	Lot #
Authorized State Agent: Mah	M REH	Date: 3-16-21
	_	r
C.		Table
Furgida	Unsi	
	fo	C about
	TO	pography
94'-	STIPOOWA	pography
94' _		
94'		
94.	73'	~250
1	59. 5Br House	<i></i>
1 4 3	50:	
Fu		1
1 Tura		i
Furury Pand		
		1
\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	Existins	1
	Barn	·
	·	
		EUTU!
/	1	Purp To Purp To 75% reduction Repair
		1
	, 1	25 %
	/ ;	reduce
	/ /	Repair
	,' /	Area
	/ /	
	/ /	
\		\$10.
	Driveway	V
	Drive 1	\downarrow
((
, , , ,	McDougald Rd (18122	

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.