Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code: SFD 2162-0103

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OLDE MILL VILLAGE
LOT 59

Owner: 210   Applicant: DAN RYAN BLSS
Address: 182 MILL BLSS   Date Evaluated: 63/10/2021
Proposed Facility: 3BR STD   Design Flow (.1949): 360GPD   Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	L 5-6%	0-10	GR LS	VM NSM					PS
		10-38	M C	FI SP	7.5YR4/6 @ 36"/34" 38				0.3
3,4	LS 6%	0-18	GR LS	VM NSM					U/PS
		18-34	M C	FI SP	7.5YR7/1 @ 30"	34			0.3

Description	Initial System	Repair System	Other Factors (.1946):
			Site Classification (.1948): PROVISIONALLY SUITABLE
Available Space (.1945)	✓	✓	Evaluated By: ANDREW CURRIN, REHS
System Type(s)	3570100	2590100	Others Present:
Site LTAR	0.3	0.3	

COMMENTS: _____

FILE #

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8		
S-SHOULDER SLOPE		LS-LOAMY SAND		VFR-VERY FRIABLE	NS-NON-STICKY
L-LINEAR SLOPE				FR-FRIABLE	SS-SLIGHTY STICKY
FS-FOOT SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
N-NOSE SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
H-HEAD SLOPE				EFI-EXTREMELY FIRM	NP-NON-PLASTIC
CC-CONCLAVE SLOPE	III	SI-SILT	0.6 - 0.3		SP-SLIGHTLY STICKY
CV-CONVEX SLOPE		SIL-SILT LOAM			P-PLASTIC
T-TERRACE		CL-CLAY LOAM			VP-VERY PLASTIC
FP-FLOOD PLAN		SCL-SANDY CLAY LOAM			
	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
SG-SINGLE GRAIN
M- MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY
PR-PRISMATIC

MINERALOGY
SLIGHTLY EXPANSIVE

EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

□ = 100 ft²

② ④

LOT 59

① ③

MONTE
TANK

SFD

D/W