

# Harnett County Department of Public Health

PERMIT # SFD 2102-0126

## Operation Permit

New Installation  Septic Tank  Nitrification Line  Repair  Expansion

PROPERTY LOCATION: 511703 Road Hill Ct Rd

Name: (owner) Victoria Wilken

SUBDIVISION Cane Mill Estates

LOT # B

System Installer: A&R Enterprises

Basement with plumbing:  Garage  Number of Bedrooms 4

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet

System Type: 25% REDUCED SYSTEM TYPE OR 6 Chamber Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

QUICKY

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.


WASTES WATERLINE DEMOL 10' OFF SYSTEM  
AND REPAIR  
PUMP + ALARM FOR FINAL.

\* 1000 GALLON TANKS USED (5 BOX REQUIRES 1000)

X PUMP + ALARM: 11/12/2021

\* INITIAL INSTAL: J. MANTART, NCHS

\* P + A FINAL: A. CURVIN, NCHS



**PERMIT CONDITIONS:**

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: \_\_\_\_\_  
Subsurface system operator required? Yes  No   
If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: \_\_\_\_\_  
V. Other: \_\_\_\_\_

\_\_\_\_\_ D-Box  \_\_\_\_\_ Pump  \_\_\_\_\_ Alarm  \_\_\_\_\_ H2O Line  \_\_\_\_\_ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system:  Conventional  Other 25% REDUCED (QUICKY-4) Septic Tank: 1000 gallons Pump Tank: 1000 gallons  
Subsurface No. of exact length 4 Chamber width of depth of  
Drainage Field ditches 2 of each ditch 150 feet ditches 3 feet ditches 24-18 inches  
French Drain Required: \_\_\_\_\_ Linear feet

Authorized State Agent [Signature] Date 11/12/2021