



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

10/14/2021

SUBJECT: SFD2103-0011
SINGLE FAMILY DWELLING

To: WEAVER HOMES INC.

Here are the results of all Inspections located at **414 SPRING HILL CHURCH RD:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks: not needed
Notes:

Inspection Type: FINAL SFD MONO**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time: 4/15/2021 AM
Completed Date/Time: 4/15/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 4/14/2021 12:48 PM WEAVER HOMES INC.

Contact Name: WEAVER HOMES INC.
Site Address: 414 SPRING HILL CHURCH RD
Phone: 9106302100
e-Mail: tammy@weaver-homes.com

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 4/16/2021 AM
Completed Date/Time: 4/16/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 4/15/2021 1:53 PM WEAVER HOMES INC.

Contact Name: WEAVER HOMES INC.
Site Address: 414 SPRING HILL CHURCH RD
Phone: 9106302100
e-Mail: tammy@weaver-homes.com

Inspection Type: SLAB
Scheduled Date/Time: 4/23/2021 AM
Completed Date/Time: 4/23/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 4/22/2021 12:11 PM WEAVER HOMES INC.

Contact Name: WEAVER HOMES INC.
Site Address: 414 SPRING HILL CHURCH RD
Phone: 9106302100
e-Mail: tammy@weaver-homes.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: T-POLE
Scheduled Date/Time: 5/6/2021 AM
Completed Date/Time: 5/6/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/5/2021 1:51 PM WEAVER HOMES INC.

Contact Name: WEAVER HOMES INC.
Site Address: 414 SPRING HILL CHURCH RD
Phone: 9106302100
e-Mail: Ashley@weaver-homes.com

Inspection Type: ROUGH IN
Scheduled Date/Time: 7/9/2021 AM
Completed Date/Time: 7/9/2021
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 7/8/2021 12:31 PM WEAVER HOMES INC.

Contact Name: WEAVER HOMES INC.
Site Address: 414 SPRING HILL CHURCH RD
Phone: 9106302100
e-Mail: Ashley@weaver-homes.com

Garage door missing. Missing Anchor bolts. Provide engineering letter on cut floor truss, osb floor truss blocking, cut top plate for header. Replace 2x6 headers on double windows. Screw tub surround. Insulate water lines in garage. Missing king studs at double windows. Add fittings to bath vent pipe. Nail plate electrical in upstairs bath.

Inspection Type: ROUGH IN
Scheduled Date/Time: 7/19/2021
Completed Date/Time: 7/19/2021
Inspector: Steven Gazlay
Result: CANCELLED
Remarks: eTRAKiT Inspection Request
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 7/19/2021
Completed Date/Time: 7/19/2021
Inspector: Steven Gazlay
Result: CANCELLED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 7/21/2021
Completed Date/Time: 7/21/2021
Inspector: Steven Gazlay
Result: CANCELLED
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: INSULATION
Scheduled Date/Time: 7/21/2021
Completed Date/Time: 7/21/2021
Inspector: Steven Gazlay
Result: CANCELLED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 8/2/2021
Completed Date/Time: 8/2/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 7/29/2021 9:08 AM WEAVER HOMES INC.

Contact Name: WEAVER HOMES INC.
Site Address: 414 SPRING HILL CHURCH RD
Phone: 9106302100
e-Mail: Ashley@weaver-homes.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 8/2/2021
Completed Date/Time: 8/2/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 7/29/2021 9:08 AM WEAVER HOMES INC.

Contact Name: WEAVER HOMES INC.
Site Address: 414 SPRING HILL CHURCH RD
Phone: 9106302100
e-Mail: Ashley@weaver-homes.com

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time: 8/5/2021
Completed Date/Time: 8/17/2021
Inspector: Oliver Tolksdorf
Result: APPROVED
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 10/11/2021
Completed Date/Time: 10/11/2021
Inspector: Scott Guy
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/7/2021 12:13 PM WEAVER HOMES INC.

Contact Name: WEAVER HOMES INC.
Site Address: 414 SPRING HILL CHURCH RD
Phone: 9106302100
e-Mail: Ashley@weaver-homes.com

No premise number provided



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 10/11/2021
Completed Date/Time: 10/11/2021
Inspector: Scott Guy
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/7/2021 12:14 PM WEAVER HOMES INC.

Contact Name: WEAVER HOMES INC.
Site Address: 414 SPRING HILL CHURCH RD
Phone: 9106302100
e-Mail: Ashley@weaver-homes.com