

SFD 2103-0013

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: *Weaver* Applicant: *364 Spring Hill Church* Date Evaluated: *3-22-21*  
 Address: *364 Spring Hill Church* Design Flow (.1949): *360 GPD* Property Size:  
 Proposed Facility: *SFD* Property Recorded:  
 Location of Site:  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L	0-8	LS(A) Gr	Fr/ns/np/np	>48"	>48"	-	-	PS .4
	<i>2-52</i>	8-16	LS Gr	Fr/ns/np/np					<u>Group III</u>
		16-48	scs sblk	Fi/ss/sp/sxp	(French Drain)				
2-3	L	0-8	LS(A) Gr	Fr/ns/np/np	>48"	>48"	-	-	PS .4
	<i>2-52</i>	8-48	scs sblk	Fi/ss/np/sxp					<u>Group III</u>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>P1</i> Evaluated By: <i>Molson RST</i> Others Present:
Available Space (.1945)	<i>✓</i>	<i>✓</i>	
System Type(s)	<i>252nd</i>	<i>252nd</i>	
Site LTAR	<i>.4</i>	<i>.4</i>	

