



TRUSSES & BEAMS
Reilly Road Industrial Park

Phone: (910) 864-8787 Fax: (910) 864-4444

deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# out not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained design the support system for all reactions that exceed 15000#.

Marshall Naylor

Mai Shan Nayior

LOAD CHART FOR JACK STUDS
(BASED ON TABLES R502.5(1) & (b))

COUNTY	Harnett
ADDRESS	Lot 11 Forest Ridge
MODEL	Roof
DATE REV. //	//
DRAWN BY	DRAWN BY Marshall Naylor
SALESMAN	SALESMAN Marshall Naylor

BUILDER A & G Residential

JOB NAME Lot 11 Forest Ridge

Lot 11 Forest Ridge

PLAN Wilmington C LSL2, RP

Wilmington C LSL2, RP

Wilmington C LSL2, RP

Wilmington C LSL2, RP

WOORE A&B RP3C

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com