Crossing at Anderson Creek 165- 111 Kensington Dr. Spring Lake, 28390 Harnett County Created: 3/1/2021 Revised: 3/26/2021 - Foundation from Slab to Crawl Space

House Plan: Braxton Elevation: C Stone/Brick Option: #1 Foundation: Crawl Foundation Finish: 3 Sides Parged Garage Hand: Right Garage: 2 Car Front Garage Door:(1) 16x8 Front Porch: Concrete Roof: Truss Siding: Vinyl Ceiling Height 1st Floor: 9' Ceiling Height 2nd Floor: 9' Door Frame Height 1st Floor: 83" Door Frame Height 2nd Floor: 83" Windows 1st Floor: 6/0 Front, 5/0 rear/sides Windows 2nd Floor: 5/0


OPTIONS


Covered Porch Study in Lieu of Dining Room Optional Mater Bath with Garden Tub Bedroom #4


Total Heated Sq. Ft.: 2207 Total Unheated Sq. Ft.: 810 Total SQ FT: 3017

Bedrooms: 4 Full Bathrooms: 2 Half Bathrooms: 1














David D Grorud (919) 601-1406 DynamicDesignGroup@gmail.com

The drawings and specifications (plans) contained on these pages are the property of Dynamic Design Group and are offered to the named client or contractor for a conditional one time use. The conditional use is limited to the lot and subdivision specified herein, and only for said location. COPYRIGHT 2019

Contractor shall verify all conditions and dimensions prior to construction. Any error or omissions shall be reported to Dynamic Design Group for corrections or justification Once construction has commenced, the contractor shall assume all responsibility.

Dimensions govern over scale, code governs over dimensions.









FIRST FLOOR PLAN SCALE: ----- 1/8" = 1'-Ø"

956 HEATED SQ. FT. 498 SQ. FT. GARAGE 132 SQ. FT. COVERED PORCH 180 SQ. FT. DECK/OPT. SCREEN PORCH


NOTES:

- IN TECHNOL (9' 11/2" FLT. HGT) INLESS OTHERWISE NOTED. 2) ALL WALLS FIGURED AT 4" WIDTHS 3) SET WINDOWS AT 1"-10" ASF. INLESS OTHERWISE NOTED.

- DIMENSIONS ARE TO FRAMING UNLESS OTHERWISE NOTED.
 CONSULT WINDOW MANUFACTURER'S SPECS. FOR EGRESS REQUIREMENTS, PRESSURE RATINGS, & ROUGH OPING'S.


OPT SCREEN PORCH/BBQ DECK







FLOOR PLAN SCALE: ---- 1/8" = 1'-0" 180 SQ. FT. SCREEN PORCH 108 SQ. FT. OPT. BBQ DECK












- UNLESS OTHERWISE NOTED. 2) ALL WALLS FIGURED AT 4" WIDTHS UNLESS OTHERWISE NOTED. 3) SET WINDOWS AT 6'-8" A.S.F.
- UNLESS OTHERWISE NOTED. 4) DIMENSIONS ARE TO FRAMING
- UNLESS OTHERWISE NOTED.
- 5) CONSULT WINDOW MANUFACTURER'S SPECS. FOR EGRESS REQUIREMENTS, PRESSURE RATINGS, & ROUGH OPNG'S.





		661 <i>0</i> NAI 1BER	L	
	A			
	B	D	®	
AMERICAN INSTITUTE OF BUILDING DESIGN				


TRIC	AL S	STMBOLS	AMERICAN INSTITUTE OF BUILDING: DESIGN
URE	\$	EXHAUST FAN	
		RECESSED SHOW	ER LIGHT
	ю	EXTERIOR FLOOD) LIGHT
_	5D	SMOKE DETECTOR	२
Æ	⊠co	CARBON MONOXI	DE DETECTOR
E	<u>~~</u>	DOOR CHIMES	
		ELECTRICAL PAN	EL
		METERBOX	
) A/C UNIT	
	φ	110 OUTLET	
	 22ø∨	220 OUTLET	
	\$	SINGLE SWITCH	
	\$3	3-WAY SWITCH	
	\$4	4-WAY SWITCH	
	GFI ₩P	OUTDOOR OUTLET	
	∯ GFI	GFI	

NAL ELECTRICAL ITEMS LIGHTS LISTED RESPECTIVE SWITCHES ARE ASSUMED					
LIGHTS					
IGHT IN LIEU OF RECESSED CANS @ KITCHEN ONLY					
IS IN LIEU OF FLUSH MOUNT					
rs					
GHTS @ KITCHEN					
INET LIGHTS					
IGHTS AT GARAGE DOOR					


























BEDROOM #4 OPTION

Bedroom #4

ELEVATION "A"



Optional Master Bath






Ц


<u>W.I.C.</u>


Ċ

OPT MASTER BATH WITH TUB










1) SEE SHEET D-1A FOR DETAILS.

2) DIMENSIONS ARE TO EXTERIOR OF FOUNDATION.

Dynamic DESIGN **GROUP**, INC David D Grorud (919) 601-1406 DynamicDesignGroup@gmail.com The drawings and specifications (plans) Ine drawings and spectrications (pinas) contained on these pages are the property of Dynamic Design Group and are offered to the named client or contractor for a conditional one time use. The conditional use is limited to the lot and subdivision specified herein, and only for said location. COPYRIGHT 2019 Contractor shall verify all conditions and dimensions prior to construction. Any error or omissions shall be reported to Dynamic Design Group for corrections or justification Once construction has commenced, the contractor shall assume all responsibility. Dimensions govern over scale, code governs over dimensions. CAPITOL PROJECT FOR: CITY HOMES LOCATION: MULTI LOT: MULTI SUBDIVISION: MULTI COUNTY: MULTI 5 25-] 6 PLAN NAME -36GR PLAN I.D. 6 \square \sim \mathbf{i} SCR PORCH /BBQ DECK \mathbf{C} J OPTIONS SHEET



HANGERS FOR I-JOISTS ARE THE RESPONSIBILITY OF THE I-JOIST SUPPLIER.





FRAMING NOTES NC (2018 NCRC): Wind: 115-120 mph

BRACING METHOD AND TYPE: CONTINUOUSLY SHEATHED WSP: CS-WSP NOTE THAT THE WALL BRACING AMOUNT PROVIDED ON THE PLANS (DETAILS AND SPECIFICATIONS) IS GREATER THAN THE AMOUNT OF MALL BRACING REQUIRED BY THE CODE. SEE NOTES BELOW FOR DETAILS AND SPECIFICATIONS FOR WALL BRACING AND WALL FRAMING.

 EXTERIOR WALL SHEATHING: WALLS SHALL BE BRACED BY SHEATHING WALLS ON ALL STORIES WITH WOOD STRUCTURAL PANEL SHEATHING (WGP) (EXPOSURE B: 71/6". EXPOSURE C: 15/32"). SHEATHING SHALL BE ATTACHED WITH 6d NAILS AT A 6"/12" NAILING PATTERN (6" OC AT PANEL EDGES AND 12" OC AT INTERMEDIATE SUPPORTS). INSTALL BLOCKING AT ALL PANEL EDGES.

3. WSP SHEATHING SHALL EXTEND TO THE UPPERMOST DOUBLE BEARING PLATE. BLOCK AT ROOF AND ATTACH BRACED WALLS PER CODE. WSP SHEATHING BETWEEN FLOORS SHALL BE SPLICED ALONG CONTINUOUS BAND OR THE WSP SHEATHING MAY BE SPLICED ACROSS STUDS (CONTINUOUS ACROSS FLOOR SYSTEM) WITH BLOCKING AT PANEL EDGES. (MINIMUM 12" BEYOND FLOOR BREAK) OR OTHER APPROVED METHOD.


"HD" = HOLDOWN: HOLD-DOWN DEVICE (NOTED AS "HD" ON PLANS) SHALL BE AN 800 POUND CAPACITY ASSEMBLY AS NOTED ON PLANS. SEE DETAILS FOR HD ASSEMBLY. **GROUND/EIRST FLOOR: USE "HD HOLD-DOWN DETAIL" ON SD SHEET

(OR EQUIV.) <u>"UPPER FLOORS:</u> ATTACH BASE OF KING STUD WITH A SIMPSON C522

STRAP DOWN ACROSS THE BAND AND DOWN TO A STUD BELOW OR HEADER BELOW. EXTEND STRAP 7" MIN ALONG EACH STUD (OR HEADER) AND ATTACH EACH END W (1) 8d NAILS.


 INTERIOR BRACED WALL: (NOTED AS "IBW" ON PLANS) ATTACH I/2" GYPSUM BOARD (GB) ON EACH SIDE OF WALL WITH A MIN. OF 5d COOLER NAILS OR #6 SCREWS @ 1" O.C. ALONG THE EDGES AND AT INTERMEDIATE SUPPORTS.

6. INTERIOR BRACED WALL-WOOD STRUCTURAL PANEL: (NOTED AS "IBM-WEP" ON PLANS). ATTACH ONE SIDE WITH 76 WEP SHEATHING WITH 86 INALLS AT A 61/12" NALLING PATTERN (6" OC AT PANEL EDGES AND 12" OC AT INTERMEDIATE SUPPORTS). INSTALL BLOCKING AT ALL PANEL EDGES. ATTACH OB OVER WEP AS REQUIRED, ATTACH OPPOSITE SIDE WITH 1/2" GB WITH A MIN. OF 54 COOLER NAILS OR #6 SCREMS @ 1" OC ALONG THE EDGES AND AT INTERMEDIATE SUPPORTS.




(A) TYP. GARAGE BEAM BEARING LVL MAIN GARAGE BEAM AS SPECIFIED - BEAM SHALL BEAR ON END PSL COLUMN -1.8E PSL COLUMN AS SPECIFIED (SEE PLANS) -2 KING STUDS ON EACH SIDE. ATTACH WITH (2) ROWS 16d NAILS AT 10" O.C. (B) TYP. GARAGE BEAM BEARING ELEVATION "C" FIRST FLOOR CEILING / STRUCTURAL PLAN 5CALE: ---------- 1/8" - 1'-0" (ROOF TRUSS) NOTES:


SHADED WALLS DENOTE LOAD BEARING WALLS.
 DENOTES SOLID STUDS.



SHEET



ROOF FRAMING PLAN



CEILING / STRUCTURAL PLAN






REFER TO "SD" SHEET(S) FOR STANDARD DETAILS, BRACING DETAILS AND STRUCTURAL NOTES.



NOTES: 1) SHADED WALLS DENOTE LOAD BEARING WALLS. 2) DENOTES SOLID STUDS. 3) SEE SHEET D-IB FOR DETAILS.







TRUSS SYSTEM REQUIREMENTS NC (2018 NCRC): Wind: 115-120 mph


- TRUSS SYSTEM LAYOUTS (PLACEMENT PLANS) SHALL BE DESIGNED IN ACCORDANCE WITH SEALED STRUCTURAL PLANS. ANY NEED TO CHANGE RUSSES SHALL BE COORDINATED WITH SOUTHERN ENGINEERS.
- 2. TRUSS SCHEMATICS (PROFILES) SHALL BE PREPARED AND SEALED BY TRUSS MANUFACTURER.
- ALL TRUSSES SHALL BE DESIGNED FOR BEARING 3 ON SPF #2 OR #3 PLATES OR LEDGERS (UNO).
- ALL REQUIRED ANCHORS FOR TRUSSES DUE TO 4 UPLIFT OR BEARING SHALL MEET THE REQUIREMENTS AS SPECIFIED ON THE TRUSS SCHEMATICS.

HEADER / BEAM NOTES

- I. ALL EXTERIOR AND LOAD BEARING HEADERS SHALL BE MIN. (2)2x6 (4" WALL) OR (3)2x6 (6 WALL) WITH (1) SUPPORT STUD AND (1) KING STUD, UNLESS NOTED OTHERWISE.
- 2. THE NUMBER SHOWN AT BEAM AND HEADER SUPPORTS INDICATES THE NUMBER OF SUPPORT STUDS REQUIRED IN STUD POCKET OR COLUMN. THE NUMBER OF KING STUDS FOR HEADERS SHALL BE ACCORDING TO ITEM "d" IN TABLE R602.3(5) OR AS BELOW: UP TO 4' SPAN: (I) KING STUD E/E
- OVER 4' AND TO 8' SPAN: (2) KING STUDS
- OVER 8' AND UP TO 10' SPAN: (3) KING STUPS E/E
- OVER IO' SPAN: (4) KING STUDS E/E









FRAMING NOTES

- FRAMING
- APPROVED METHOD
- (OR EQUIV.)
- NTERMEDIATE SUPPORTS
 - SUPPORTS.



REC. ROOM / BEDROOM #4 OPTION



2)

3)

4)

(5.)

6)

1

8

٠


٠

REQUIRED

PROVIDED

VALLEYS

HEIGHT)



TRUSS SYSTEM REQUIREMENTS NG (2018 NGRC): Wind: 115-120 mph

- TRUSS SYSTEM LAYOUTS (PLACEMENT PLANS) 1 SHALL BE DESIGNED IN ACCORDANCE WITH SEALED STRUCTURAL PLANS. ANY NEED TO CHANGE TRUSSES SHALL BE COORDINATED WITH SOUTHERN ENGINEERS.
- 2. TRUSS SCHEMATICS (PROFILES) SHALL BE PREPARED AND SEALED BY TRUSS MANUFACTURER.
- ALL TRUSSES SHALL BE DESIGNED FOR BEARING З. ON SPF #2 OR #3 PLATES OR LEDGERS (UNO).
- 4. ALL REQUIRED ANCHORS FOR TRUSSES DUE TO UPLIFT OR BEARING SHALL MEET THE REQUIREMENTS AS SPECIFIED ON THE TRUSS SCHEMATICS.





ROOF FRAMING NOTES: NC (2018 NCRC): Wind: 115-120 mph

(1) 2x8 @ 16" O.C. WITH 2x10 RIDGE, UNO.

(2) 2x10 OR 1.75x11.875 LVL HIP. (2) 2x10 HIPS MAY BE SPLICED WITH A MIN. 6'-0" OVERLAP AT CENTER

(2) 2x10 OR 1.75x9.25 LVL VALLEY. DO NOT SPLICE

1.75x11.875 LVL OR (2)1.75x9.25 LVL VALLEY

FALSE FRAME VALLEY ON 2x10 FLAT PLATE

2x6 RAFTERS @ 16" O.C. W/ 2x8 RIDGE, UNO.


2x10 RAFTERS @ 16" 0.C. W 2x12 RIDGE, UNO.

EXTEND RIDGE 12" BEYOND INTERSECTION

"SR" = SINGLE RAFTER "DR" = DOUBLE RAFTER "TR" = TRIPLE RAFTER


"RS" = ROOF SUPPORT " $_$ " = (3) STUD OR 4x4 POST FOR ROOF SUPPORT (USE 2X6 OR 6X6 FOR SUPPORT POSTS OVER IO'-O" IN

ATTACH VAULTED RAFTERS WITH HURRICANE CLIPS: SIMPSON "H-2.5A" OR EQUIVALENT INSTALL RAFTER TIES AND COLLAR TIES PER SECTION R802.3.1 OF THE 2018 NC RESIDENTIAL CODE.






NOTES: 1) SEE SHEET D-IB FOR DETAILS. 2) DIMENSIONS ARE FROM EXT. OF FRAMING TO CENTER LINE OF RIDGE.





STRUCTURAL NOTES

NC (2018 NCRC): Wind: 115-120 mph


- I. ENGINEER'S SEAL APPLIES ONLY TO STRUCTURAL COMPONENTS INCLUDING ROOF RAFTERS, HIPS, VALLEYS, RIDGES, FLOORS, WALLS, BEAMS AND HEADERS, COLUMNS, CANTILEVERS, OFFSET LOAD BEARING WALLS, PIER & GIRDER SYSTEM, FOOTING, AND PILING SYSTEM. ENGINEER'S SEAL DOES NOT CERTIFY DIMENSIONAL ACCURACY OR ARCHITECTURAL LAYOUT INCLUDING ROOF SYSTEM. ALL REQUIREMENTS FOR PROFESSIONAL CERTIFICATION SHALL BE PROVIDED BY THE APPROPRIATE PROFESSIONAL. SOUTHERN ENGINEERS, P.A. CERTIFIES ONLY THE STRUCTURAL COMPONENTS AS SPECIFICALLY STATED.
- 2. ALL CONSTRUCTION SHALL CONFORM TO THE LATEST REQUIREMENTS OF RESIDENTIAL CODE, ALL CONSTRUCTION SHALL CONTROL TO THE LATED REQUISITED OF RESIDENTIAL COUL, PLUS ALL LOCAL CODES AND REGULATIONS. THE STRUCTURAL ENGINEER IS NOT RESPONSIBLE FOR, AND WILL NOT HAVE CONTROL OF, CONSTRUCTION MEANS, METHODS, TECHNIQUES, SEQUENCES OR PROCEDURES, OR FOR SAFETY PRECAUTIONS AND PROGRAMS IN CONNECTION WITH THE CONSTRUCTION WORK, NOR WILL THE ENGINEER BE RESPONSIBLE FOR THE CONTRACTOR'S FAILURE TO CARRY OUT THE CONSTRUCTION WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS. "CONSTRUCTION REVIEW" SERVICES ARE NOT PART OF OUR CONTRACT. ALL MEMBERS SHALL BE FRAMED ANCHORED, TIED AND BRACED IN ACCORDANCE WITH GOOD CONSTRUCTION PRACTICE AND THE BUILDING CODE.
- DESIGN LOADS (LISTED AS: LIVE LOAD, DEAD LOAD, DEFLECTION)
- ROOMS OTHER THAN SLEEPING ROOMS: (40 PSF, 10 PSF, L/360) SLEEPING ROOMS: (30 PSF, 10 PSF, L/360)
- ATTIC WITH PERMANENT STAIR: (40 PSF, 10 PSF, L/360) ATTIC WITHOUT PERMANENT STAIR: (20 PSF, 10 PSF, L/360)
- ATTIC WITHOUT STORAGE: (IO PSF, IO PSF, L/240)
- STAIRS: (40 PSF. 10 PSF. L/360)
- EXTERIOR BALCONIES: (60 PSF, 10 PSF, L/360)
- DECKS: (40 PSF, 10 PSF, L/360) GUARDRAILS AND HANDRAILS: (200 LBS)
- PASSSENGER VEHICLE GARAGES: (50 PSF, 10 PSF, L/360)
- FIRE ESCAPES: (40 PSF, 10 PSF, L/360)
- SNOW: (20 PSF)
- WALLS SHALL BE BRACED BY SHEATHING WALLS ON ALL STORIES WITH WOOD STRUCTURAL PANELS. SEE FRAMING NOTES FOR THICKNESS AND NAILING REQUIREMENTS.
- 5. SEE APPENDIX M (DCA6) FOR EXTERIOR DECK REQUIREMENTS INCLUDING ATTACHMENTS FOR LATERAL LOADS.
- 6. CONCRETE SHALL HAVE A MINIMUM 28 DAY STRENGTH OF 3000 PSI AND A MAXIMUM SLUMP OF 5 INCHES UNLESS NOTED OTHERNISE (UNO). AIR ENTRAINED PER TABLE 402.2. ALL CONCRETE SHALL BE PROPORTIONED, MIXED, HANDLED, SAMPLED, TESTED, AND PLACED IN ACCORDANCE WITH ACLISTANDARDS ALL SAMPLES FOR PUMPING SHALL BE TAKEN FROM THE EXIT END OF THE PUMP, CONTROL JOINTS IN SLABS SHALL BE SPACED ON A GRID OF +-30 TIMES THE DEPTH (D), CONTROL JOINTS HALL BE SANCUT TO A DEPTH OF I/D, (I.E. 4" CONCRETE SLABS SHALL HAVE 1/4" DEEP CONTROL JOINTS SAWCUT IN SLAB ON A +-IO'-O" x +-IO'-O" GRID).
- ALLOWABLE SOIL BEARING PRESSURE ASSUMED TO BE 2000 PSF. THE CONTRACTOR MUST CONTACT A GEOTECHNICAL ENGINEER AND THE STRUCTUAL ENGINEER IF UNSATISFACTORY SUBSURFACE CONDITIONS ARE ENCOUNTERED. THE SURFACE AREA ADJACENT TO THE FOUNDATION WALL SHALL BE PROVIDED WITH ADEQUATE DRAINAGE, AND SHALL BE GRADED SO AS TO DRAINSURFACE WATER AWAY FROM FOUNDATION WALLS.
- 8. ALL FRAMING LUMBER SHALL BE SPF #2 (Fb = 875 PSI) UNLESS NOTED OTHERWISE (UNO). ALL TREATED LUMBER SHALL BE SYP # 2. PLATE MATERIAL MAY BE SPF # 3 OR SYP #3 (Fc(perp) = 425 PSI - MIN).
- L.V.L. SHALL BE LAMINATED VENEER LUMBER: Fb=2600 P5I, Fv=285 P5I, E=1.9x10 P5I.
 9.L. 95.L. 9HALL BE PARALLEL STRAND LUMBER: Fb=2400 P5I, Fv=240 P5I, E=2.0x10 P5I.
 9.2. L.SL. 9HALL BE LAMINATED STRAND LUMBER: Fb=2250 P5I, Fv=400 P5I, E=1.55x10 P5I.
 INSTALL ALL CONVECTIONS PER MANUFACTURERS INSTRUCTIONS.
- IO. ALL ROOF TRUSS AND I-JOIST LAYOUTS SHALL BE PREPARED IN ACCORDANCE WITH THE SEALED STRUCTURAL DRAWINGS. TRUSSES AND I-JOISTS SHALL BE INSTALLED ACCORDING TO THE MANUFACTURE'S SPECIFICATIONS. ANY CHANGE IN TRUSS OR I-JOIST LAYOUT SHALL BE COORDINATED WITH SOUTHERN ENGINEERS.
- ALL STRUCTURAL STEEL SHALL BE ASTM A-36. STEEL BEAMS SHALL BE SUPPORTED AT EACH END WITH A MINIMUM BEARING LENGTH OF 3 1/2" INCHES AND FULL FLANGE WIDTH. PROVIDE SOLID BEARING FROM BEAM SUPPORT TO FOUNDATION. BEAMS SHALL BE ATTACHED TO EACH SUPPORT WITH TWO LAG SCREWS (I/2" DIAMETER x 4" LONG). LATERAL SUPPORT IS CONSIDERED ADEQUATE PROVIDING THE JOIST ARE TO ENALI ED TO THE SOLE PLATE AND SOLE PLATE IS NAILED OR BOLTED TO THE BEAM FLANGE @ 48" O.C. ALL STEEL TUBING SHALL BE ASTM A500. LAP ALL REBAR SPLICES 30 BAR DIAMETERS.
- 12. REBAR SHALL BE DEFORMED STEEL, ASTM615, GRADE 60.
- 13. FLITCH BEAMS SHALL BE BOLTED TOGETHER USING (2) ROWS OF 1/2" DIAMETER BOLTS (ASTM A325) WITH WASHERS PLACED UNDER THE THREADED END OF BOLT BOLTS SHALL BE SPACED AT 24" O.C. (MAX), AND STAGGERED AT THE TOP AND BOTTOM OF BEAM (2" EDGE DISTANCE), WITH 2 BOLTS LOCATED AT 6" FROM EACH END.
- 14. BRICK LINTELS (WHEN REQUIRED) SHALL BE 3 1/2"x3 1/2"x1/4" STEEL ANGLE FOR UP TO 6'-0" SPAN AND 6'x4'x5/0' STELL ANGLE WITH 6" LEG VERTICAL FOR SPANS UP TO 4'-0". SEE PLANS FOR SPANS OVER 4'-0". SEE ALSO SECTION RT03.1.3 LINTELS.







(B) CS-PF: CONTINUOUS PORTAL FRAME CONSTRUCTION DETAIL AND APPLICATION BASED ON NCRC FIGURE R602.IO.I - PORTAL FRAME CONSTRUCTION



(2) SIMPSON CSI6 STRAP

WITH 8d NAILS. (EXTEND TO WALL TOP PLATE AND

ATTACH KING STUD TO SUPPORT STUDS WITH IOd NAILS @ 8" OC.


MIN (2)2X SUPPORT STUDS


AND (I) KING STUD (SEE PLAN FOR STUD COLUMN


REQUIREMENTS)


EXTEND 20" UNDER


HEADER)














SIDING AS SPECIFIED

2 × 4 STUDS # 16" O.C.

2 × 4 TREATED SILL

8" SOLID MASONRY CA

1/2 SHEATHING

4" BRICK

4" CMU

FARTH

SEE FOUNDATION PLAN FOR FOOTING SIZE

F-16 ,

HORIZ MASONRY

D

F-18A

