

March 25, 2021

ph: 910-893-7547

fax: 910-893-9371

Benjamin Stout Real Estate

RE: Existing Tank Application #SFD2103-0044

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal.

2. Have system pumped out

3. Replace Sanitary Tee with Filter

4. Other – Uncover and break loose the lids for the septic and pump tank, and move the house box so as to meet the 5 foot setback from the septic system.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Program Specialist
Harnett County Department of Public Health

MO/KH
Copy - Central Permitting