

A & G Residential
916 Arsenal Ave
Suite B
Fayetteville, NC 28305

04/26/2021

Attention : Jamie Godwin
Matt English

RE: Daily Field Report for 04/23/2021
200 Meldoy Lane (CMT) Cameron, NC
Building & Earth Project No : RD210267

Ladies and Gentlemen:

On this date, representative(s) of Building & Earth were present to perform construction material testing services at this project site. Our testing and observations for this date include the following:

ST-1 : In place field density testing was performed for Finished Subgrade Soils -Building. The field density testing was performed in general accordance with ASTM D1556, using the results of field one-point as compared to the laboratory proctors. One(1) in-place field density test was performed on this date. The testing results indicate that in-place compaction and moisture content at the location and depth tested meet or exceed the specified requirements outlined in the project plans and specifications. For additional details of our testing, please refer to the attached Field Density Test Report.

Closing

The testing and observations identified above have been reviewed by our project manager. If you have questions regarding this information, please do not hesitate to contact us.

Respectfully Submitted,
Building & Earth Sciences, LLP

Enclosures : ST-1



Rachael Heath

Reviewed By



ST-1

Test Date: 04/23/2021
 Field Technician: James Johnson
 Tests requested by: N/R
 Results provided to: N/R

Report of Field Density Testing

Project Name: 200 Meldoy Lane (CMT) Cameron, NC Ambient Temperature: 50-70
 Project Number: RD210267 Weather: Partly Cloudy
 Project Location: Cameron, NC Wind Conditions: Moderate
 Client: A & G Residential Results Provided To: N/R
 Contractor: A & G Residential Superintendent: N/R

- Notes:
- 1 Test location by technician
 - 2 Elevation by Technician
 - 3 Fill/backfill placed prior to technician arriving

Design & Specification Data

Area ID	Area Description	Depth (ft)	Test Method	% Compaction	Moisture Range	
					Min	Max
FSG-Bldg	Finished Subgrade Soils -Building	0.0 - 2.0	ASTM D-698	95 %	- 10.0	+ 10.0

Laboratory Proctors

Proctor ID	Description of Material	USCS/AASHTO	Maximum Dry Density (pcf)	Optimum Moisture Content (%)
1-point			113.0	13.0%

Density Test Data

Test #	IDs		Test Type	Location	Probe Depth (in)	Elev. (ft)	Dry Density(pcf)	% Moisture	% Compaction	Result
	Area	Proctor								
1	FSG-Bldg	1-point	ASTMD1556	Finished Subgrade Soils -Building : Meldoy Lane Center of Lot :		FSG	114.1	4.8	100+	PASS

Equipment Used: Standard Counts: Density:
 Last Calibration: Moisture:

Rachael Heath

Reviewed By

Photographs

