



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

5/16/2022

SUBJECT: SFD2103-0060
SINGLE FAMILY DWELLING

To: SHERMAN JENYFER LEE

Here are the results of all Inspections located at **2886 HILLMON GROVE RD:**

Inspection Type: WATER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: INSULATION SFD MONO
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: RESIDENTIAL FIRE WALL
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: FINAL SFD MONO**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: ENVIR WELL FINAL
Scheduled Date/Time:
Completed Date/Time:
Inspector: EH Bucket
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks: not required
Notes:

Inspection Type: MONO SLAB SFD MONO
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN SFD MONO
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: ADDRESS
Scheduled Date/Time: 10/28/2021
Completed Date/Time: 10/29/2021
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 2876 HILLMON GROVE RD CAMERON 28326

Inspection Type: UNDER SLAB TRADES SFD MONO
Scheduled Date/Time: 1/28/2022
Completed Date/Time: 1/28/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Must have plan reviewed plans onsite with plan review stamp.

Inspection Type: T-POLE
Scheduled Date/Time: 1/28/2022
Completed Date/Time: 1/28/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: UNDER SLAB TRADES SFD MONO
Scheduled Date/Time: 2/2/2022
Completed Date/Time: 2/2/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: MONO SLAB SFD MONO

Scheduled Date/Time: 2/10/2022

Completed Date/Time: 2/10/2022

Inspector: Steven Gazlay

Result: DISAPPROVED

Remarks:

Notes: Provide engineering letter of pad fill. Wrap pipes in contact with concrete. Vapor barrier not installed. Must have continuous footings across garage door openings.

Inspection Type: MONO SLAB SFD MONO

Scheduled Date/Time: 2/17/2022

Completed Date/Time: 2/17/2022

Inspector: Steven Gazlay

Result: APPROVED

Remarks:

Notes: Dan left message stating letter in box, I called him to tell him to either send letter or upload in portal, received vmail is full.

Inspection Type: ENVIR OPERATIONS PERMIT

Scheduled Date/Time: 4/26/2022

Completed Date/Time: 4/26/2022

Inspector: Mark Osborne

Result: APPROVED

Remarks:

Notes:

Inspection Type: ROUGH IN SFD MONO

Scheduled Date/Time: 5/10/2022

Completed Date/Time: 5/10/2022

Inspector: Slade Burton Lawson III

Result: DISAPPROVED

Remarks:

Notes: Inspector SPG changed the inspection assignment from SPG to SBL
Paperwork to complete inspection not in job box

Inspection Type: ROUGH IN SFD MONO

Scheduled Date/Time: 5/12/2022

Completed Date/Time: 5/12/2022

Inspector: Steven Gazlay

Result: DISAPPROVED

Remarks:

Notes: Block frame fly rafters. Missing insulation stops and depth gauges. Nail lvl's. Missing 2" square washers and straps on portal frame. Screw tub surround. Seal plumbing pipes to slab. Seal top of furred wall. Nail j2gr hanger. Pressure test down. Nail structural nail plate.