Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 111 Hazelwood Rd. (Neills Crk. Rd. - SR 1 ISSUED TO: Watermark Homes Inc. SUBDIVISION South Creek Site Improvements required prior to Construction Authorization Issuance: NEW X REPAIR Type of Structure: 61x59 sfd, 3 beds 2 baths Proposed Wastewater System Type: 25% Reduction Sys. Projected Daily Flow: 360 Number of Occupants: 6 Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities Pump Required: XYes No Type of Water Supply: Community Public Well Distance from well NA feet X Five years Permit valid for: No expiration Permit conditions: 04/07/2021 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules . 1950, . 1952, . 1954, . 1955, . 1956, . 1957, . 1958, and . 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Watermark Homes Inc. PROPERTY LOCATION: 111 Hazelwood Rd. (Neills Crk. Rd. - SF SUBDIVISION South Creek Facility Type: 61x59 sfd, 3 beds 2 baths New Expansion Basement Fixtures? Yes Basement? Yes × No 25% NEONCTION STOTIEM (Initial) Wastewater Flow Type of Wastewater System** (See note below, if applicable) 25% NESNOTION SID, Number of trenches ____3 Installation Requirements/Conditions Exact length of each trench 90 Septic Tank Size 1000 gallons Trenches shall be installed on contour at a Pump Tank Size 1000 gallons Maximum Trench Depth of: 20 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ______ft. TDH vs. _____GPM inches below pipe ~A inches above pipe Aggregate Depth: Conditions: PUMP TO MEDIUM D-BOX EGUAL DISTRIBUTIO WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 64/07/2021 Authorized State Agent: Construction Authorization Expiration Date: 64/07/2021

ANDREW WITH

Harnett County Department of Public Health Site Sketch


Property Location: 111 Hazelw	ood Rd. (Neills Crk. Rd SR 1513)
-------------------------------	----------------------------------

Issued To: Watermark Homes Inc. Subdivision South Creek Lot # 67

Authorized State Agent: Date: CH/67/2021

ANDREW CUMIN

* FOSTALL AS HIGH UPHILL AS CONTOUR ALLOWS



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.