

SFD 2103-0096

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: *Prime ESTATA* Applicant: *4-8-21*
 Address: *1464 Cypress Church Rd* Date Evaluated: *4-8-21*
 Proposed Facility: *SFD* Design Flow (.1949): *360 GPD* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L	0-6	LS(A) Gr	Fr/us/np/nxp	10YR 7/2 ≤ 12"	>48"	-	-	U
	2-5%	6-12	LS Gr	Fr/us/np/nxp	10YR 6/2 ≤ 14"				
		12-48	SCI SBk	Fi/ss/sp/xp	10YR 6/2 ≥ 36"				
213 4.5	L	0-6	LS(A) Gr	Fr/us/np/nxp	10YR 7/2 ≤ 12"	>48"	-	-	PS .4
	5-10%	6-10	LS Gr	Fr/us/np/nxp	10YR 6/2 ≤ 16"				(Group III)
		10-48	SCI SBk	Fi/ss/sp/xp	10YR 7/2 ≥ 36"				

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>M Osborn-RETT</i> Others Present:
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<i>252cmd</i>	<i>252cmd</i>	
Site LTAR	<i>.4</i>	<i>.4</i>	

