

29' 3 3/4"

4" 21'8

COMTECH ROOF & FLOOR ROOF & FLOOR TRUSSES & BEAMS Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444									
deeme require attache Code r founda require but not profess suppor those s registe design exceed	Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 1500#. A registered design professional shall be retained to design the support system for all reactions that exceed to studes.								
	(BASED	ON TABL	OR JA((b) & (b)					
NOR NO NO NO NO NO NO NO NO NO NO NO NO NO	ee korsaa Ngoveration 1 2 3 4 5 6 7 8 9) 2) 3 0 4 0 5	20112342 20212342 2021 2021 2021 2021 2021 2021 2021 20	(0:40) 004 sques 0.62 00 1 00 2 00 3 00 4				
Harnett	Dove Rd.	Floor	//	DRAWN BY David Landry	SALESMAN Marshall Naylor				
COUNTY	ADDRESS	MODEL	DATE REV.	DRAWN BY	SALESMAN				
Ben Stout Real Estate	Lot 5 Spartan Ridge	The Williams	N/A	Ouote #	J0221-0896				
BUI LDER	JOB NAME	PLAN	SEAL DATE	QUOTE #	JOB #				
THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com									

Dimension Notes All exterior wall to wall dimensions are to face of sheathing unless noted otherwise
All interior wall dimensions are to face of frame wall unless noted otherwise
All exterior wall to truss dimensions are to face of frame wall unless noted otherwise

All Walls Shown Are Considered Load Bearing

Plumbing Drop Notes Plumbing drop locations shown are NOT exact.
Contractor to verify ALL plumbing drop locations prior to setting Floor Trusses.
Adjust spacing as needed not to exceed 24"oc.

Connector Information					Nail Information	
Sym	Product	Manuf	Qty	Supported Member	Header	Truss
\bigcirc	MSH422	USP	6	Varies	10d/3"	10d/3"

Products							
PlotID	Length	Product	Plies	Net Qty			
BM1	4' 0"	2x10 SPF No.2	2	2			
BM2	12' 0"	2x12 SPF No.2	2	4			
GDH	24' 0"	1-3/4"x 14" LVL Kerto-S	2	2			

Truss Placement Plan Scale: 1/4"=1'