

Jeanann Dawson

From: DJ Tyndall <dgtyndalljr@gmail.com>
Sent: Wednesday, August 4, 2021 9:08 AM
To: Jeanann Dawson
Subject: Re: Detached garage
Attachments: SKM_30821080409110.pdf

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Headers over garage will be 11 7/8" double lvl
Header for lean to will be double 9 1/4" lvl

Please let me know if we need anything additional. Brad can call me at 9108903402 if he has any questions

Sent from my iPhone

On Aug 3, 2021, at 2:03 PM, Jeanann Dawson <jdawson@harnett.org> wrote:

Plans disapproved: Here are remarks from Brad

<image001.png>

Jeanann Dawson
Central Permitting Technician
Department of Development Services
Central Permitting Division
420 McKinney Pkwy
Lillington, NC 27546
Phone: 910-893-7525
Direct: 910-814-6421
Fax: 910-893-2793
jdawson@harnett.org