

Enoch Engineers, P.A.

Consulting Engineers & Surveyors

1403 NC Highway 50 South
Benson, North Carolina 27504

Phone: (919) 894-5731
(919) 894-7765

WEB: enochengineers.com

EMAIL: general@enochengineers.com

Joe E Godwin Sr., PE, PLS

Jason E. Godwin, PLS

Fleet Temple, PE

May 24, 2021

Freedom Contractors of Dunn
Post Office Box 608
Dunn, North Carolina 28335

Attn: Mr. Tim Tart


Re: Foundation inspection

Subject: Permit No. SFD2104-0064
3721 Bunnlevel Erwin Road
Erwin, North Carolina 28339


To Whom It May Concern:

Enoch Engineers conducted a site inspection, Thursday May 20th, 2021 for the subject site above. At this time, we observed that root material, unsuitable soil material and organics were removed in several locations of the excavated footings. We recommend backfilling these areas with washed aggregate No. 57 stone. We certify the footing soil and stone meet a minimum bearing capacity of 2,000 lb/ft² and are constructed in accordance to 2018 North Carolina Building Code for residential footings. If you have any questions please reach our office at (919) 894-7765 or jason@enochengineers.com.

Respectfully



Joe E. Godwin, Sr., PE
Enoch Engineers, PA



JEG/jeg