

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Keith Bullock Bldg Inc. PROPERTY LOCATION: Wilburn Road (SR 1432) SUBDIVISION LOT # 3
NEW [x] REPAIR [] EXPANSION []
Type of Structure: 3BR 60'x60' STD
Proposed Wastewater System Type: 25% Reduction Sys.
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement [] Yes [x] No
Pump Required: [] Yes [] No [x] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [x] Public [] Well Distance from well _____ feet
Permit valid for: [x] Five years [] No expiration
Permit conditions: _____

Authorized State Agent: [Signature] Date: 03/06/2018 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Keith Bullock Bldg Inc. PROPERTY LOCATION: Wilburn Road (SR 1432) SUBDIVISION LOT # 3
Facility Type: 3BR 60'x60' STD [x] New [] Expansion [] Repair
Basement? [] Yes [x] No Basement Fixtures? [] Yes [] No
Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable [])
25% Reduction Sys. (Repair)
Installation Requirements/Conditions
Septic Tank Size 1000 gallons Exact length of each trench 75 feet Trench Spacing: 9 Feet on Center
Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 12 inches
Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: NA inches below pipe
Conditions: On Contour D-Box Equal Distribution Required NA inches above pipe
NA inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 03/06/2018
Construction Authorization Expiration Date: 03/06/2023

HTE# 18-5-43389

Permit # 29908

Harnett County Department of Public Health Site Sketch

ISSUED TO: Keith Bullock Bld Inc. PROPERTY LOCATOR: Wiburn Road (SR 1432)
SUBDIVISION _____ LOT # _____

Authorized State Agent: Andrew Curran Date: 03/06/2018

