
Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 381 Countryside

ISSUED TO: McKee Homes	SUBDIVISION Oakmont	iti yotao	LOT # 86
NEW REPAIR EXPANSION Type of Structure: SFD (42'x57')		equired prior to Construction Author	rization Issuance:
Proposed Wastewater System Type: Pump to 25% Red St	'S		
Projected Daily Flow: 360 GPD			
Number of bedrooms: 3 Number of Occupants: 6	max		
Basement Yes X No			
Pump Required:	nal location and elevations of facilities		_
Type of Water Supply: Community Public Well I	istance from well feet	Permit valid for:	▼ Five years
Permit conditions:			■ No expiration
	0/17/01		
	26hs Date: 6/17/21		ACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.			
Cor	struction Authorization		
	(Required for Building Permit)		
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, with the attached system layout.	1957, 1958, and 1959 are incorporated by reference	es into this permit and shall be met. System	s shall be installed in accordance
ISSUED TO: McKee Homes	PROPERTY LOCATION: 381	Countryside	
	SUBDIVISION Oakmont		LOT # 86
Facility Type: SFD (42'x57')			
Basement? Yes No Basement Fixtures? Yes			
	tion System	(Initial) Wastewater Flow.	360 GPD
,	tion bystem	(IIIILIAI) WASLEWALET TION.	010
(See note below, if applicable)	`		
Pump to 25% Red S			
<u>Installation Requirements/Conditions</u> Number of			
Septic Tank Size 1000 gallons Exact length	of each trench 60 feet	Trench Spacing: 9	
Pump Tank Size 1000 gallons Trenches sh	III be installed on contour at a	Soil Cover: 6	inches
Maximum To	ench Depth of: 18inches	(Maximum soil cover shall	not exceed
	oms shall be level to +/-1/4"	36" above the trench bot	ttom)
in all direct	ons)		150
Pump Requirements:ft. TDH vsGPM			inches below pipe
Tump requirements.		Aggregate Depth:	inches above pipe
Conditions: Permit based on proposal from ag	nlicants I SS	Aggregate peptili.	inches total
conditions: remit based on proposal nom ap	plicarits Loo.		inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FRO NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD		REPAIR AREA.	
**If applicable: I understand the system type specified is different to	om the type specified on the application	on. I accept the specifications of	this permit.
wner/Legal Representative Signature: Date:			
This Construction Authorization is subject to revocation if the site plan, plat, or the intended	d use changes. The Construction Authorization shall no		ownership of the site. This
Construction Authorization is subject to compliance with the provisions of the Laws and Ru			ATTACHED SITE SKETCH
	9		
The Mariana	Date:	6/17/2010	
Authorized state Agent.			
Construction Authorization Expiration Date: 6/17/2026			

Harnett County Department of Public Health Site Sketch



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.