Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 4923 Barbecue Church Rd (SR1209) ISSUED TO: Weaver Homes SUBDIVISION REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 26' x 49' SFD Proposed Wastewater System Type: 25% reduction Projected Daily Flow: 360 Number of Occupants: 6 Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities No Pump Required: Yes X Five years Type of Water Supply: Community Public Well Distance from well feet Permit valid for: No expiration Permit conditions: Date: 06-03-21 SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958 and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 4923 Barbecue Church Rd (SR1209) ISSUED TO: Weaver Homes SUBDIVISION Facility Type: 26' x 49' SFD Expansion Repair ➤ New Basement? Yes X No Basement Fixtures? Yes X No 25% reduction (Initial) Wastewater Flow: 360 Type of Wastewater System** GPD (See note below, if applicable) 25% reduction Number of trenches 3 Installation Requirements/Conditions Septic Tank Size 1000 gallons Exact length of each trench 75 Trench Spacing: 9 Feet on Center Trenches shall be installed on contour at a Soil Cover: 6 Pump Tank Size _____ gallons Maximum Trench Depth of: 18" - 24" inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) inches below pipe Pump Requirements: ft. TDH vs. ___inches above pipe Conditions: French drain 15' upslope of first septic line behind the house inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Mal H REHS Date: 06-03-21 Construction Authorization Expiration Date: 06-03-26

Harnett County Department of Public Health Site Sketch

Property Location: 4923 Barbecue		1
ssued To: Weaver Homes	Subdivision	Lot #
Authorized State Agent:		Date: 06-03-21
	FUTUR 25% reduction Repair Area	
	1 Repair Area	
	(225 7072/)	1
	19'	
	$\frac{1}{19}$ $\frac{1}{19}$ $\frac{1}{19}$, ,)
	French Draid!	5')
	- French Drait	-1
	1 8 5	
	1990	
	MAGNOLIA MAGNOLIA MAGNOLIA	
		1
	20,41 20,51	ナー
	Re Pal	
	The Day of the Control of the Contro	-
	1 3	
	355B	
		\-t
		1209)
	Barbecue Church Rd	5/2
	- Church 120	
	i we Cho	
	Labeco	

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.